

Fume Hoods Status

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/11/2017	3018 WESTERN AVENUE	224	Regional Primate Research Center	1833	Active	Passed	64	124	24	40
8/11/2017	3018 WESTERN AVENUE	43	Regional Primate Research Center	1632	Active	Passed	64	121	24	64
8/11/2017	3018 WESTERN AVENUE	21	Regional Primate Research Center	1631	Active	Passed	60	97	24	40
5/17/2017	401 QUEEN ANNE AVE N	119	Northwest Lipid Research Clinic	1890	Active	Passed	63	102	22	40
5/17/2017	401 QUEEN ANNE AVE N	112	Northwest Lipid Research Clinic	1889	Active	Passed	61	112	20	50
8/14/2017	AEROSPACE/ENGR RESEARCH	318	Bioengineering	895	Active	Passed	68	106	24	60
8/14/2017	AEROSPACE/ENGR RESEARCH	323	Bioengineering	1019	Active	Passed	67	123	18	60
8/14/2017	AEROSPACE/ENGR RESEARCH	323	Bioengineering	155	Active	Passed	64	85	18	36
8/14/2017	AEROSPACE/ENGR RESEARCH	323	Bioengineering	154	Active	Passed	65	79	18	36
8/14/2017	AEROSPACE/ENGR RESEARCH	317	Bioengineering	1602	Active	Passed	60	140	18	64
8/14/2017	AEROSPACE/ENGR RESEARCH	318	Bioengineering	1232	Active	Failed	67	145	18	60
5/2/2017	ARCF - ANIMAL RSCH CARE FAC	B-160	Comparative Medicine	2548	Active	Passed	60	78	18	48
5/2/2017	ARCF - ANIMAL RSCH CARE FAC	B-238	Comparative Medicine	2549	Active	Passed	56	77	18	58
7/21/2017	ART BUILDING	201-B	School of Art	265	Active	Passed	71	113	18	48
7/21/2017	ART BUILDING	201-B	School of Art	267	Active	Passed	71	123	22	48
7/21/2017	ART BUILDING	201-B	School of Art	266	Active	Passed	70	135	18	48
8/15/2017	ART BUILDING	123 D	School of Art	1060	Active	Failed	70	150	18	38
3/28/2017	ATMOS SCI/GEOPHYSICS	510	Atmospheric Sciences	150	Active	Passed	67	100	23	50
3/30/2017	ATMOS SCI/GEOPHYSICS	325	Atmospheric Sciences	1574	Active	Passed	67	95	22	40

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/29/2017	ATMOS SCI/GEOPHYSICS	056	Quaternary Research Center	757	Active	Passed	64	108	20	50
11/29/2017	ATMOS SCI/GEOPHYSICS	155	Earth , Space and Science	568	Active	Passed	62	107	18	38
11/29/2017	ATMOS SCI/GEOPHYSICS	044A	Quaternary Research Center	571	Active	Passed	65	99	33	38
11/29/2017	ATMOS SCI/GEOPHYSICS	056	Quaternary Research Center	756	Active	Passed	62	109	21	50
11/29/2017	ATMOS SCI/GEOPHYSICS	056B	Quaternary Research Center	758	Active	Passed	67	101	18	50
11/29/2017	ATMOS SCI/GEOPHYSICS	044	Quaternary Research Center	570	Active	Passed	64	108	32	38
3/5/2018	ATMOS SCI/GEOPHYSICS	034	Quaternary Research Center	569	Active	Passed	60	100	21	50
1/30/2017	BAGLEY HALL	453	Chemistry	2062	Active	Passed	52	75	18	62
1/30/2017	BAGLEY HALL	453	Chemistry	2061	Active	Passed	51	67	18	62
1/30/2017	BAGLEY HALL	454A	Chemistry	2535	Active	Passed	51	72	18	62
1/30/2017	BAGLEY HALL	458A	Bioengineering	1615	Active	Passed	68	102	26	60
1/30/2017	BAGLEY HALL	459	Chemistry	2059	Active	Passed	53	84	18	62
1/30/2017	BAGLEY HALL	467	Bioengineering	1614	Active	Passed	51	112	18	60
1/30/2017	BAGLEY HALL	459	Chemistry	2060	Active	Passed	52	68	18	62
1/31/2017	BAGLEY HALL	411	Chemistry	1803	Active	Passed	55	98	18	72
1/31/2017	BAGLEY HALL	411	Chemistry	2063	Active	Passed	57	72	18	72
1/31/2017	BAGLEY HALL	411	Chemistry	2064	Active	Passed	56	80	18	72
1/31/2017	BAGLEY HALL	411	Chemistry	2065	Active	Passed	58	61	18	72
1/31/2017	BAGLEY HALL	411	Chemistry	2066	Active	Passed	52	78	18	72
1/31/2017	BAGLEY HALL	402	Chemistry	1802	Active	Passed	51	97	24	80
2/13/2017	BAGLEY HALL	398D	Chemistry	2088	Active	Passed	58	107	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/13/2017	BAGLEY HALL	365	Chemistry	1741	Active	Passed	68	102	26	60
2/13/2017	BAGLEY HALL	336A	Chemistry	1813	Active	Passed	71	95	27	64
2/13/2017	BAGLEY HALL	336A	Chemistry	1812	Active	Passed	72	94	27	64
2/13/2017	BAGLEY HALL	336A	Chemistry	1811	Active	Passed	72	117	27	64
2/13/2017	BAGLEY HALL	336A	Chemistry	1810	Active	Passed	68	98	27	64
2/13/2017	BAGLEY HALL	336A	Chemistry	1809	Active	Passed	68	117	27	64
2/13/2017	BAGLEY HALL	336A	Chemistry	1808	Active	Passed	67	119	27	64
2/13/2017	BAGLEY HALL	336B	Chemistry	1807	Active	Passed	68	110	25	64
2/13/2017	BAGLEY HALL	336B	Chemistry	1806	Active	Passed	67	111	25	64
2/13/2017	BAGLEY HALL	339	Chemistry	354	Active	Passed	72	113	26	40
2/13/2017	BAGLEY HALL	392	Chemistry	2092	Active	Passed	57	72	18	72
2/13/2017	BAGLEY HALL	362A	Chemistry	829	Active	Passed	74	101	28	60
2/13/2017	BAGLEY HALL	398D	Chemistry	2089	Active	Passed	51	67	18	72
2/13/2017	BAGLEY HALL	388	Chemistry	2096	Active	Passed	61	74	18	72
2/13/2017	BAGLEY HALL	366	Chemistry	1739	Active	Failed	65	116	18	52
2/13/2017	BAGLEY HALL	393	Chemistry	2083	Active	Passed	59	62	18	72
2/13/2017	BAGLEY HALL	397C	Chemistry	2087	Active	Passed	60	73	18	72
2/13/2017	BAGLEY HALL	397C	Chemistry	2086	Active	Passed	60	68	18	72
2/13/2017	BAGLEY HALL	397C	Chemistry	2085	Active	Passed	61	73	18	72
2/13/2017	BAGLEY HALL	397C	Chemistry	2084	Active	Passed	63	98	18	72
2/13/2017	BAGLEY HALL	398	Chemistry	2091	Active	Passed	52	74	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/13/2017	BAGLEY HALL	398D	Chemistry	2090	Active	Passed	53	67	18	72
2/13/2017	BAGLEY HALL	362	Chemistry	1818	Active	Passed	76	114	28	40
2/13/2017	BAGLEY HALL	365	Chemistry	1740	Active	Passed	67	99	26	60
2/28/2017	BAGLEY HALL	326	Chemistry	130	Active	Passed	64	79	29	48
2/28/2017	BAGLEY HALL	326	Chemistry	1742	Active	Passed	62	99	26	50
2/28/2017	BAGLEY HALL	320	Chemistry	2546	Active	Passed	54	74	18	54
2/28/2017	BAGLEY HALL	314	Chemistry	133	Active	Passed	60	98	21	50
2/28/2017	BAGLEY HALL	306	Chemistry	129	Active	Passed	54	107	21	50
3/3/2017	BAGLEY HALL	014	Chemistry	318	Active	Passed	64	99	18	60
3/3/2017	BAGLEY HALL	014	Chemistry	319	Active	Passed	68	96	22	60
3/3/2017	BAGLEY HALL	016	Chemistry	1856	Active	Passed	63	84	18	62
3/3/2017	BAGLEY HALL	016	Chemistry	1857	Active	Passed	65	85	18	62
3/3/2017	BAGLEY HALL	023	Chemistry	323	Active	Passed	71	82	18	84
3/3/2017	BAGLEY HALL	005	Chemistry	449	Active	Passed	65	88	29	60
3/8/2017	BAGLEY HALL	206	Chemistry	451	Active	Passed	64	110	23	50
3/8/2017	BAGLEY HALL	233	Chemistry	2318	Active	Passed	56	104	18	62
3/8/2017	BAGLEY HALL	233	Chemistry	2319	Active	Passed	55	99	18	62
3/8/2017	BAGLEY HALL	220	Chemistry	2458	Active	Passed	60	112	18	88
3/8/2017	BAGLEY HALL	205	Chemistry	450	Active	Passed	60	100	21	60
3/8/2017	BAGLEY HALL	220	Chemistry	2457	Active	Passed	56	77	18	88
3/20/2017	BAGLEY HALL	152-B	Chemistry	1843	Active	Passed	56	92	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/20/2017	BAGLEY HALL	171	Chemistry	369	Active	Passed	52	103	18	40
3/20/2017	BAGLEY HALL	171	Chemistry	370	Active	Passed	53	92	18	40
3/20/2017	BAGLEY HALL	171	Chemistry	371	Active	Passed	54	131	20	88
3/20/2017	BAGLEY HALL	162-B	Chemistry	1845	Active	Passed	55	98	18	62
3/20/2017	BAGLEY HALL	152-C	Chemistry	1842	Active	Passed	57	87	18	62
3/20/2017	BAGLEY HALL	152-B	Chemistry	1844	Active	Passed	55	84	18	62
3/20/2017	BAGLEY HALL	133D	Chemistry	334	Active	Passed	62	120	18	48
3/20/2017	BAGLEY HALL	128	Chemistry	329	Active	Passed	59	105	24	40
3/20/2017	BAGLEY HALL	087	Chemistry	337	Active	Passed	57	109	24	88
3/20/2017	BAGLEY HALL	083A	Chemistry	365	Active	Passed	61	93	18	40
3/20/2017	BAGLEY HALL	083	Chemistry	1587	Active	Passed	62	104	20	36
3/20/2017	BAGLEY HALL	152A	Chemistry	1846	Active	Passed	56	90	18	62
3/21/2017	BAGLEY HALL	082	Chemistry	1556	Active	Passed	63	106	22	60
3/21/2017	BAGLEY HALL	073	Chemistry	326	Active	Passed	64	98	26	38
3/21/2017	BAGLEY HALL	192	Chemistry	998	Active	Passed	64	117	18	50
3/21/2017	BAGLEY HALL	082C	Chemistry	1008	Active	Passed	64	105	20	88
3/22/2017	BAGLEY HALL	192	Chemistry	999	Active	Passed	65	115	24	50
3/22/2017	BAGLEY HALL	192	Chemistry	1002	Active	Passed	62	124	24	50
3/22/2017	BAGLEY HALL	192	Chemistry	1003	Active	Passed	60	149	23	50
3/22/2017	BAGLEY HALL	192	Chemistry	1005	Active	Passed	58	109	26	50
3/22/2017	BAGLEY HALL	192	Chemistry	1049	Active	Passed	60	94	23	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/22/2017	BAGLEY HALL	192	Chemistry	1004	Active	Passed	59	104	24	50
3/22/2017	BAGLEY HALL	192	Chemistry	1050	Active	Passed	62	93	29	50
3/22/2017	BAGLEY HALL	192	Chemistry	1051	Active	Passed	58	111	25	50
3/22/2017	BAGLEY HALL	192	Chemistry	1052	Active	Passed	60	113	27	50
3/22/2017	BAGLEY HALL	192	Chemistry	1053	Active	Passed	60	101	22	50
3/22/2017	BAGLEY HALL	192	Chemistry	1054	Active	Passed	58	126	22	50
3/22/2017	BAGLEY HALL	192	Chemistry	1055	Active	Passed	61	118	24	50
3/22/2017	BAGLEY HALL	192	Chemistry	1056	Active	Passed	60	100	25	50
3/22/2017	BAGLEY HALL	192	Chemistry	1007	Active	Passed	61	104	20	50
3/22/2017	BAGLEY HALL	192	Chemistry	1006	Active	Passed	58	120	24	50
3/29/2017	BAGLEY HALL	030	Chemistry	324	Inactive	Failed	40	26	18	48
3/29/2017	BAGLEY HALL	063B	Chemistry	325	Inactive	Failed	0	0	0	
3/29/2017	BAGLEY HALL	092	Chemistry	1009	Active	Failed	0	0	0	50
3/29/2017	BAGLEY HALL	208	Chemistry	452	Active	Passed	68	118	28	50
3/29/2017	BAGLEY HALL	291B	Chemistry	433	Active	Passed	61	81	24	88
3/31/2017	BAGLEY HALL	006	Chemistry	317	Inactive	Passed	0	0	18	40
3/31/2017	BAGLEY HALL	020	Chemistry	322	Active	Passed	66	119	22	48
4/17/2017	BAGLEY HALL	152C	Chemistry	1841	Active	Passed	56	117	18	62
5/23/2017	BAGLEY HALL	192	Chemistry	1001	Active	Passed	61	93	18	50
5/23/2017	BAGLEY HALL	192	Chemistry	1000	Active	Passed	63	100	18	50
12/29/2017	BAGLEY HALL	270	Chemistry	412	Active	Passed	58	86	17	40

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/13/2018	BAGLEY HALL	133	Chemistry	330	Active	Failed	69	110	29	36
3/13/2018	BAGLEY HALL	293	Chemistry	440	Active	Passed	64	77	17	45
3/13/2018	BAGLEY HALL	293	Chemistry	441	Active	Passed	64	103	17	45
3/13/2018	BAGLEY HALL	293	Chemistry	442	Active	Passed	64	147	15	45
3/13/2018	BAGLEY HALL	133	Chemistry	333	Active	Failed	68	96	29	84
3/13/2018	BAGLEY HALL	293	Chemistry	438	Active	Passed	66	99	24	60
3/13/2018	BAGLEY HALL	293	Chemistry	443	Active	Passed	65	111	15	45
3/13/2018	BAGLEY HALL	293	Chemistry	439	Active	Passed	66	92	24	60
3/13/2018	BAGLEY HALL	293	Chemistry	444	Active	Failed	64	69	25	45
3/13/2018	BAGLEY HALL	293	Chemistry	445	Active	Passed	64	126	17	45
3/13/2018	BAGLEY HALL	133	Chemistry	331	Active	Passed	71	104	29	36
3/13/2018	BAGLEY HALL	293	Chemistry	448	Active	Passed	65	133	17	45
3/13/2018	BAGLEY HALL	191	Chemistry	1900	Active	Passed	61	70	18	86
3/13/2018	BAGLEY HALL	293	Chemistry	447	Active	Failed	65	167	17	45
3/13/2018	BAGLEY HALL	234	Unknown	2532	Active	Passed	60	108	18	63
3/13/2018	BAGLEY HALL	293	Chemistry	436	Active	Passed	65	105	24	48
3/13/2018	BAGLEY HALL	293	Chemistry	437	Active	Passed	65	119	24	48
3/13/2018	BAGLEY HALL	133	Chemistry	332	Active	Passed	72	103	25	84
3/13/2018	BAGLEY HALL	234	Unknown	2531	Active	Passed	61	121	18	63
3/13/2018	BAGLEY HALL	191	Chemistry	1901	Active	Passed	62	96	18	86
3/13/2018	BAGLEY HALL	191	Chemistry	1893	Active	Passed	63	82	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/13/2018	BAGLEY HALL	191	Chemistry	1892	Active	Passed	62	76	18	86
3/13/2018	BAGLEY HALL	191	Chemistry	1894	Active	Passed	62	84	18	86
3/13/2018	BAGLEY HALL	191	Chemistry	1896	Active	Passed	63	81	18	86
3/13/2018	BAGLEY HALL	191	Chemistry	1897	Active	Passed	63	81	18	86
3/13/2018	BAGLEY HALL	191	Chemistry	1898	Active	Passed	63	78	18	86
3/13/2018	BAGLEY HALL	236	Unknown	2529	Active	Passed	61	98	18	63
3/13/2018	BAGLEY HALL	191	Chemistry	1899	Active	Passed	61	70	18	38
3/13/2018	BAGLEY HALL	191	Chemistry	1895	Active	Passed	63	89	18	86
3/13/2018	BAGLEY HALL	236	Unknown	2530	Active	Passed	61	116	18	63
3/14/2018	BAGLEY HALL	235	Chemistry	2317	Active	Passed	61	89	18	62
3/14/2018	BAGLEY HALL	291-b	Chemistry	2231	Active	Passed	61	61	18	60
3/14/2018	BAGLEY HALL	291-b	Chemistry	2232	Active	Passed	62	62	18	60
3/14/2018	BAGLEY HALL	291-c	Chemistry	2233	Active	Passed	60	72	18	63
3/14/2018	BAGLEY HALL	290D	Chemistry	2072	Active	Passed	53	71	18	38
3/14/2018	BAGLEY HALL	290C	Chemistry	2071	Active	Passed	55	80	18	86
3/14/2018	BAGLEY HALL	290C	Chemistry	2070	Active	Passed	56	77	18	86
3/14/2018	BAGLEY HALL	235	Chemistry	2316	Active	Passed	61	111	18	62
3/16/2018	BAGLEY HALL	411	Chemistry	2068	Active	Passed	60	100	18	72
3/19/2018	BAGLEY HALL	442	Bioengineering	1609	Active	Passed	65	160	18	50
3/19/2018	BAGLEY HALL	442	Bioengineering	1613	Active	Passed	71	136	18	50
3/19/2018	BAGLEY HALL	442B	Bioengineering	1607	Active	Failed	66	153	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/19/2018	BAGLEY HALL	442	Chemistry	2057	Active	Passed	64	101	18	86
3/19/2018	BAGLEY HALL	442	Bioengineering	1610	Active	Passed	65	108	18	50
3/19/2018	BAGLEY HALL	442	Bioengineering	1611	Active	Passed	64	113	18	50
3/19/2018	BAGLEY HALL	333	Chemistry	1566	Active	Passed	72	104	27	52
3/19/2018	BAGLEY HALL	442	Chemistry	2056	Active	Passed	67	84	18	86
3/19/2018	BAGLEY HALL	442	Bioengineering	1608	Active	Passed	67	105	18	50
3/19/2018	BAGLEY HALL	442	Bioengineering	1612	Active	Passed	68	124	18	50
3/19/2018	BAGLEY HALL	411	Chemistry	2067	Active	Passed	60	100	18	62
3/19/2018	BAGLEY HALL	442-A	Chemistry	1834	Active	Passed	68	120	23	60
3/19/2018	BAGLEY HALL	442A	Bioengineering	1606	Active	Passed	69	122	18	60
3/19/2018	BAGLEY HALL	333	Chemistry	1567	Active	Passed	72	111	27	52
3/19/2018	BAGLEY HALL	333	Chemistry	1569	Active	Passed	71	96	27	52
3/19/2018	BAGLEY HALL	333	Chemistry	1568	Active	Passed	69	99	27	52
3/19/2018	BAGLEY HALL	291-a	Chemistry	2229	Active	Passed	62	64	18	60
3/19/2018	BAGLEY HALL	291-a	Chemistry	2230	Active	Passed	62	63	18	60
3/19/2018	BAGLEY HALL	442	Chemistry	2058	Active	Failed	65	105	18	76
3/21/2018	BAGLEY HALL	388	Chemistry	2098	Active	Passed	60	69	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2081	Active	Passed	62	77	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2102	Active	Passed	60	78	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2076	Active	Passed	63	81	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2099	Active	Passed	63	90	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/21/2018	BAGLEY HALL	389A	Chemistry	2075	Active	Passed	63	86	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2073	Active	Passed	64	67	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2080	Active	Passed	62	80	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2101	Active	Passed	61	70	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2077	Active	Passed	64	73	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2095	Active	Passed	62	74	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2094	Active	Passed	60	94	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2093	Active	Passed	61	72	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2082	Active	Passed	59	59	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2078	Active	Passed	64	82	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2097	Active	Passed	62	79	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2074	Active	Passed	63	83	18	72
3/21/2018	BAGLEY HALL	388	Chemistry	2100	Active	Passed	62	76	18	72
3/21/2018	BAGLEY HALL	389A	Chemistry	2079	Active	Passed	63	80	18	72
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2191	Active	Passed	62	74	18	53
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2192	Active	Passed	62	77	18	53
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2190	Active	Passed	62	78	18	53
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2189	Active	Passed	63	93	18	53
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2188	Active	Passed	60	67	18	53
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2200	Active	Passed	61	78	18	53
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2186	Active	Passed	61	77	18	53

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/24/2018	BEN HALL INT. RSCH	680-D	Radiation Oncology	2050	Active	Passed	60	109	18	62
1/24/2018	BEN HALL INT. RSCH	680	Radiation Oncology	2052	Active	Passed	61	71	18	62
1/24/2018	BEN HALL INT. RSCH	680	Radiation Oncology	2051	Active	Passed	61	78	18	62
1/24/2018	BEN HALL INT. RSCH	630	Radiation Oncology	2187	Active	Passed	62	67	18	53
1/25/2018	BEN HALL INT. RSCH	620-L	Radiation Oncology	2197	Active	Passed	63	93	18	53
1/25/2018	BEN HALL INT. RSCH	620F	Radiation Oncology	2185	Active	Passed	61	67	18	53
1/25/2018	BEN HALL INT. RSCH	620-D	Mechanical Engineering	2193	Active	Passed	60	65	18	53
1/25/2018	BEN HALL INT. RSCH	620-E	Bioengineering	2194	Active	Passed	60	64	18	53
1/25/2018	BEN HALL INT. RSCH	620-J	Radiation Oncology	2196	Active	Passed	62	91	18	53
1/25/2018	BEN HALL INT. RSCH	620-M	Radiation Oncology	2198	Active	Passed	63	69	18	53
1/25/2018	BEN HALL INT. RSCH	620-D	Institute for Public Policy and Management	2199	Active	Passed	63	84	18	53
1/26/2018	BEN HALL INT. RSCH	620-G	Radiation Oncology	2195	Active	Passed	63	84	18	53
1/31/2018	BEN HALL INT. RSCH	426	Bioengineering	1998	Active	Passed	63	116	18	38
1/31/2018	BEN HALL INT. RSCH	409	Bioengineering	1994	Active	Passed	63	123	18	62
1/31/2018	BEN HALL INT. RSCH	432	Bioengineering	2002	Active	Passed	64	111	18	62
1/31/2018	BEN HALL INT. RSCH	415	Bioengineering	1996	Active	Passed	64	118	18	62
1/31/2018	BEN HALL INT. RSCH	415	Bioengineering	1995	Active	Passed	65	140	18	62
1/31/2018	BEN HALL INT. RSCH	418	Bioengineering	1997	Active	Passed	63	133	18	62
1/31/2018	BEN HALL INT. RSCH	432	Bioengineering	2000	Active	Failed	69	253	18	62
1/31/2018	BEN HALL INT. RSCH	432	Bioengineering	1999	Active	Passed	65	120	18	62
1/31/2018	BEN HALL INT. RSCH	478C	Civil Engineering	2053	Active	Passed	62	77	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/31/2018	BEN HALL INT. RSCH	492	Applied Physics Laboratory	2218	Active	Passed	60	85	18	62
1/31/2018	BEN HALL INT. RSCH	432	Bioengineering	2001	Active	Passed	63	105	18	62
1/31/2018	BEN HALL INT. RSCH	491	Applied Physics Laboratory	2217	Active	Passed	62	67	18	62
1/31/2018	BEN HALL INT. RSCH	478B	Civil Engineering	2054	Active	Failed	62	82	18	50
2/5/2018	BEN HALL INT. RSCH	533	Applied Physics Laboratory	2215	Active	Passed	58	80	18	82
2/5/2018	BEN HALL INT. RSCH	362	Applied Physics Laboratory	2256	Active	Passed	61	71	18	38
2/5/2018	BEN HALL INT. RSCH	361	College of Engineering	2255	Active	Passed	61	86	18	62
2/5/2018	BEN HALL INT. RSCH	533	Applied Physics Laboratory	2214	Active	Passed	60	61	18	68
2/5/2018	BEN HALL INT. RSCH	568	Applied Physics Laboratory	2212	Active	Passed	60	78	18	62
2/5/2018	BEN HALL INT. RSCH	310	Applied Physics Laboratory	2105	Active	Passed	59	72	18	52
2/5/2018	BEN HALL INT. RSCH	308	Applied Physics Laboratory	2103	Active	Passed	59	89	18	62
2/5/2018	BEN HALL INT. RSCH	365	Applied Physics Laboratory	2257	Active	Failed	60	106	18	38
2/5/2018	BEN HALL INT. RSCH	309	Applied Physics Laboratory	2104	Active	Passed	62	92	18	62
2/5/2018	BEN HALL INT. RSCH	311	Applied Physics Laboratory	2106	Active	Passed	62	79	18	62
2/5/2018	BEN HALL INT. RSCH	566	Applied Physics Laboratory	2213	Active	Passed	62	84	18	46
2/5/2018	BEN HALL INT. RSCH	361	College of Engineering	2254	Active	Passed	59	65	18	62
10/5/2017	BENSON HALL	033	Chemical Engineering	1858	Active	Passed	55	101	18	62
10/5/2017	BENSON HALL	B 05	Chemical Engineering	880	Active	Passed	62	102	28	64
10/5/2017	BENSON HALL	B 05	Chemical Engineering	170	Active	Passed	66	128	24	48
10/5/2017	BENSON HALL	B 21	Chemical Engineering	171	Active	Passed	64	109	20	60
10/5/2017	BENSON HALL	015	Chemical Engineering	2166	Active	Passed	62	80	18	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/5/2017	BENSON HALL	013	Chemical Engineering	2165	Active	Passed	62	84	18	38
10/5/2017	BENSON HALL	B 20	Chemical Engineering	174	Active	Failed	63	126	18	60
10/5/2017	BENSON HALL	035	Chemical Engineering	1848	Active	Passed	63	101	18	62
10/5/2017	BENSON HALL	B 03B	Chemical Engineering	1617	Active	Passed	57	115	18	36
10/5/2017	BENSON HALL	035	Chemical Engineering	1849	Active	Passed	64	99	18	62
10/12/2017	BENSON HALL	127	Chemical Engineering	2161	Active	Passed	62	70	18	60
10/12/2017	BENSON HALL	235	Chemical Engineering	161	Active	Passed	59	110	18	36
10/12/2017	BENSON HALL	231	Chemical Engineering	160	Active	Passed	60	84	18	36
10/12/2017	BENSON HALL	220	Chemical Engineering	159	Inactive	Failed	0	0	0	36
10/12/2017	BENSON HALL	121	Chemical Engineering	913	Active	Passed	59	120	24	36
10/12/2017	BENSON HALL	209	Chemical Engineering	156	Active	Passed	60	95	18	36
10/12/2017	BENSON HALL	205	Chemical Engineering	173	Active	Passed	61	98	18	36
10/12/2017	BENSON HALL	213	Chemical Engineering	157	Active	Passed	60	124	18	36
10/12/2017	BENSON HALL	227	Chemical Engineering	563	Active	Passed	63	136	24	36
10/12/2017	BENSON HALL	211	Chemical Engineering	158	Active	Passed	62	104	18	36
10/13/2017	BENSON HALL	313	Chemical Engineering	164	Active	Passed	63	129	24	36
10/13/2017	BENSON HALL	336	Chemical Engineering	168	Active	Passed	62	109	18	48
10/13/2017	BENSON HALL	336	Chemical Engineering	169	Active	Passed	62	107	18	48
10/13/2017	BENSON HALL	340	Chemical Engineering	561	Active	Passed	64	89	20	36
10/13/2017	BENSON HALL	341	Chemical Engineering	562	Active	Passed	61	87	18	36
10/13/2017	BENSON HALL	311	Chemical Engineering	2020	Active	Passed	62	92	18	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/13/2017	BENSON HALL	327	Chemical Engineering	565	Active	Passed	65	111	24	36
10/13/2017	BENSON HALL	317	Chemical Engineering	163	Active	Passed	62	97	18	36
10/13/2017	BENSON HALL	321	Chemical Engineering	166	Active	Passed	65	95	24	36
10/13/2017	BENSON HALL	309	Chemical Engineering	162	Active	Passed	61	86	18	36
10/13/2017	BENSON HALL	301	Chemical Engineering	165	Active	Passed	63	113	18	36
10/13/2017	BENSON HALL	247	Chemical Engineering	564	Active	Passed	61	100	18	36
10/13/2017	BENSON HALL	335	Chemical Engineering	560	Active	Passed	61	113	18	36
10/13/2017	BENSON HALL	331	Chemical Engineering	167	Active	Passed	62	116	18	36
7/28/2017	BLOEDEL HALL	208	Forest Management and Engineering Division	19	Active	Passed	64	127	28	44
7/28/2017	BLOEDEL HALL	209	Forest Management and Engineering Division	21	Active	Passed	72	118	24	44
7/28/2017	BLOEDEL HALL	178	Forest Management and Engineering Division	1159	Active	Passed	74	102	28	44
7/28/2017	BLOEDEL HALL	170	Forest Management and Engineering Division	1156	Inactive	Passed	72	145	18	44
7/28/2017	BLOEDEL HALL	108	Forest Management and Engineering Division	2314	Active	Passed	64	76	18	62
7/28/2017	BLOEDEL HALL	209	Forest Management and Engineering Division	341	Active	Failed	73	115	24	36
7/28/2017	BLOEDEL HALL	014	Forest Management and Engineering Division	14	Active	Failed	68	116	20	44
7/28/2017	BLOEDEL HALL	211	Forest Management and Engineering Division	24	Active	Passed	70	81	21	44
7/28/2017	BLOEDEL HALL	209	Forest Management and Engineering Division	22	Active	Passed	64	100	24	44
7/28/2017	BLOEDEL HALL	238	Forest Management and Engineering Division	40	Active	Passed	70	86	28	68

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/28/2017	BLOEDEL HALL	254	Forest Management and Engineering Division	2069	Active	Passed	75	113	18	40
7/28/2017	BLOEDEL HALL	260	Forest Management and Engineering Division	1160	Active	Passed	73	99	18	44
7/28/2017	BLOEDEL HALL	308	Forest Management and Engineering Division	27	Active	Passed	67	104	28	44
7/28/2017	BLOEDEL HALL	312	Forest Management and Engineering Division	28	Active	Passed	65	97	28	44
7/28/2017	BLOEDEL HALL	214	Forest Management and Engineering Division	25	Inactive	Passed	65	136	28	44
7/28/2017	BLOEDEL HALL	337	Forest Management and Engineering Division	1082	Active	Passed	71	107	24	70
7/28/2017	BLOEDEL HALL	314	Forest Management and Engineering Division	30	Active	Passed	68	125	28	44
7/28/2017	BLOEDEL HALL	340	Forest Management and Engineering Division	38	Active	Passed	70	115	28	44
7/28/2017	BLOEDEL HALL	354	Forest Management and Engineering Division	41	Active	Passed	75	100	18	44
7/28/2017	BLOEDEL HALL	360	Forest Management and Engineering Division	42	Inactive	Failed	0	0	18	44
7/28/2017	BLOEDEL HALL	M06A	Forest Management and Engineering Division	18	Active	Passed	74	115	22	35
7/28/2017	BLOEDEL HALL	M14A	Forest Management and Engineering Division	16	Active	Failed	72	193	18	58
7/28/2017	BLOEDEL HALL	M16A	Forest Management and Engineering Division	17	Active	Passed	72	110	18	58
7/28/2017	BLOEDEL HALL	313	Forest Management and Engineering Division	29	Active	Passed	67	107	24	44
7/28/2017	BLOEDEL HALL	210	Forest Management and Engineering Division	20	Active	Passed	67	117	18	44
7/28/2017	BLOEDEL HALL	108	Forest Management and Engineering Division	2315	Active	Failed	70	96	28	33

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/28/2017	BLOEDEL HALL	338	Forest Management and Engineering Division	37	Active	Passed	72	116	28	44
7/28/2017	BLOEDEL HALL	211	Forest Management and Engineering Division	23	Active	Passed	66	132	35	58
9/14/2017	Bothell Beardslee	274	School of Medicine	2253	Active	Passed	66	73	18	62
9/14/2017	Bothell Beardslee	270	School of Medicine	2251	Active	Passed	67	93	18	62
9/14/2017	Bothell Beardslee	273	School of Medicine	2252	Active	Passed	65	76	18	38
9/21/2017	Bothell Beardslee	226	School of Medicine	2454	Active	Passed	64	98	18	72
9/14/2017	Bothell Cascadia 1	CC 320	Science	1762	Active	Passed	66	92	18	62
9/14/2017	Bothell Cascadia 1	CC 302	Science	1765	Active	Passed	67	113	18	62
9/14/2017	Bothell Cascadia 1	CC 330	Science	1763	Active	Passed	69	94	18	62
9/14/2017	Bothell Cascadia 1	CC 330	Science	1764	Active	Passed	68	106	18	62
9/14/2017	Bothell Cascadia 1	CC 331	Science	2234	Active	Passed	63	84	18	62
9/14/2017	Bothell Cascadia 1	CC 340	Science	1767	Active	Passed	69	120	18	62
9/14/2017	Bothell Cascadia 1	CC 340	Science	1766	Active	Passed	69	118	18	62
7/19/2017	Bothell Discovery Hall	467	School of STEM	2505	Active	Passed	61	67	18	63
7/19/2017	Bothell Discovery Hall	280 A	School of STEM	2523	Active	Passed	63	110	18	43
7/19/2017	Bothell Discovery Hall	367	School of STEM	2521	Active	Passed	62	73	18	36
7/19/2017	Bothell Discovery Hall	472	School of STEM	2519	Active	Passed	61	82	18	36
7/19/2017	Bothell Discovery Hall	267	School of STEM	2525	Active	Passed	60	85	18	63
7/19/2017	Bothell Discovery Hall	474	School of STEM	2517	Active	Passed	58	75	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2516	Active	Passed	60	83	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/19/2017	Bothell Discovery Hall	469	School of STEM	2515	Active	Passed	61	107	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2514	Active	Passed	60	109	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2513	Active	Passed	60	102	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2512	Active	Passed	60	102	18	63
7/19/2017	Bothell Discovery Hall	474	School of STEM	2518	Active	Passed	61	72	18	63
7/19/2017	Bothell Discovery Hall	263	School of STEM	2524	Active	Passed	60	86	18	63
7/19/2017	Bothell Discovery Hall	262	School of STEM	2526	Active	Passed	67	100	18	68
7/19/2017	Bothell Discovery Hall	463	School of STEM	2503	Active	Passed	60	69	18	63
7/19/2017	Bothell Discovery Hall	262	School of STEM	2527	Active	Passed	68	111	18	70
7/19/2017	Bothell Discovery Hall	469	School of STEM	2511	Active	Passed	61	108	18	63
7/19/2017	Bothell Discovery Hall	463	School of STEM	2502	Active	Passed	60	76	18	63
7/19/2017	Bothell Discovery Hall	463	School of STEM	2501	Active	Passed	58	73	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2506	Active	Passed	60	112	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2507	Active	Passed	61	96	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2508	Active	Passed	60	103	18	63
7/19/2017	Bothell Discovery Hall	463	School of STEM	2504	Active	Passed	60	63	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2509	Active	Passed	61	103	18	63
7/19/2017	Bothell Discovery Hall	469	School of STEM	2510	Active	Passed	60	103	18	63
9/14/2017	Bothell UWII (Merrit)	UW2 231	Undergraduate Studies Program	1824	Active	Passed	67	98	18	50
9/14/2017	Bothell UWII (Merrit)	UW2 241	Undergraduate Studies Program	1827	Active	Passed	71	96	18	62
9/14/2017	Bothell UWII (Merrit)	UW2 241	Undergraduate Studies Program	1826	Active	Passed	71	120	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/14/2017	Bothell UWII (Merrit)	UW2 235	Undergraduate Studies Program	1825	Active	Passed	66	89	18	50
9/14/2017	Bothell UWII (Merrit)	UW2 231	Undergraduate Studies Program	1823	Active	Passed	67	97	18	50
8/24/2017	BURKE MUSEUM	112	Geological Sciences	1636	Active	Passed	68	139	18	38
8/24/2017	BURKE MUSEUM	206	Biology Program	1106	Active	Passed	66	83	29	60
8/24/2017	BURKE MUSEUM	017-C	Geological Sciences	1109	Active	Passed	65	123	18	60
8/24/2017	BURKE MUSEUM	114	Geological Sciences	1117	Active	Passed	67	134	24	38
8/24/2017	BURKE MUSEUM	206	Biology Program	1107	Active	Passed	67	122	18	36
8/24/2017	BURKE MUSEUM	028	Geological Sciences	1108	Active	Passed	68	127	28	36
8/24/2017	CHDD CLINIC	CD050	Otolaryngology/Head and Neck Surgery	1551	Active	Passed	66	127	24	62
8/24/2017	CHDD CLINIC	CD186D	Otolaryngology/Head and Neck Surgery	1553	Active	Passed	67	121	28	62
8/24/2017	CHDD CLINIC	CD186A	Otolaryngology/Head and Neck Surgery	1552	Active	Passed	64	131	18	62
8/24/2017	CHDD CLINIC	CD198	Neurology	1554	Active	Passed	65	135	18	62
4/7/2017	Chemistry Building	112	Chemistry	1300	Active	Passed	63	94	18	74
4/7/2017	Chemistry Building	111	Chemistry	1277	Active	Passed	63	100	18	86
4/7/2017	Chemistry Building	111	Chemistry	1267	Active	Passed	61	110	18	86
4/7/2017	Chemistry Building	111	Chemistry	1266	Active	Passed	62	101	18	86
4/7/2017	Chemistry Building	112	Chemistry	1309	Active	Passed	61	105	18	86
4/7/2017	Chemistry Building	112	Chemistry	1307	Active	Passed	61	97	18	86
4/7/2017	Chemistry Building	112	Chemistry	1305	Active	Passed	59	113	18	86
4/7/2017	Chemistry Building	112	Chemistry	1303	Active	Passed	62	115	18	86
4/7/2017	Chemistry Building	112	Chemistry	1301	Active	Passed	62	122	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/7/2017	Chemistry Building	112	Chemistry	1308	Active	Passed	61	94	18	86
4/7/2017	Chemistry Building	112	Chemistry	1299	Active	Passed	62	111	18	86
4/7/2017	Chemistry Building	112	Chemistry	1298	Active	Passed	62	118	18	86
4/7/2017	Chemistry Building	112	Chemistry	1297	Active	Passed	61	104	18	86
4/7/2017	Chemistry Building	118	Chemistry	1310	Active	Passed	60	92	18	62
4/7/2017	Chemistry Building	121A	Chemistry	1280	Active	Failed	60	100	18	62
4/7/2017	Chemistry Building	111	Chemistry	1278	Active	Passed	62	118	18	86
4/7/2017	Chemistry Building	111	Chemistry	1279	Active	Passed	62	99	18	86
4/7/2017	Chemistry Building	108	Chemistry	1294	Active	Failed	60	125	18	50
4/7/2017	Chemistry Building	127	Chemistry	1293	Active	Passed	62	110	18	86
4/7/2017	Chemistry Building	108	Chemistry	1295	Active	Passed	62	118	18	50
4/7/2017	Chemistry Building	104	Chemistry	1296	Active	Passed	59	98	27	38
4/7/2017	Chemistry Building	112	Chemistry	1302	Active	Passed	61	106	18	86
4/7/2017	Chemistry Building	127	Chemistry	1292	Active	Passed	63	119	18	86
4/7/2017	Chemistry Building	128	Chemistry	1320	Active	Passed	61	100	18	86
4/7/2017	Chemistry Building	128	Chemistry	1319	Active	Passed	63	118	18	86
4/7/2017	Chemistry Building	128	Chemistry	1318	Active	Passed	62	94	18	86
4/7/2017	Chemistry Building	128	Chemistry	1317	Active	Passed	61	107	18	86
4/7/2017	Chemistry Building	128	Chemistry	1316	Active	Passed	63	118	18	86
4/7/2017	Chemistry Building	128	Chemistry	1314	Active	Passed	63	97	18	86
4/7/2017	Chemistry Building	128	Chemistry	1313	Active	Passed	64	89	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/7/2017	Chemistry Building	128	Chemistry	1321	Active	Passed	62	100	18	86
4/7/2017	Chemistry Building	111	Chemistry	1268	Active	Passed	63	106	18	86
4/7/2017	Chemistry Building	128	Chemistry	1311	Active	Passed	60	121	18	86
4/7/2017	Chemistry Building	111	Chemistry	1276	Active	Passed	61	102	18	86
4/7/2017	Chemistry Building	112	Chemistry	1306	Active	Passed	59	85	18	62
4/7/2017	Chemistry Building	111	Chemistry	1274	Active	Passed	60	103	18	86
4/7/2017	Chemistry Building	111	Chemistry	1269	Active	Passed	61	105	18	38
4/7/2017	Chemistry Building	111	Chemistry	1270	Active	Passed	64	123	18	38
4/7/2017	Chemistry Building	111	Chemistry	1271	Active	Passed	62	118	18	62
4/7/2017	Chemistry Building	111	Chemistry	1272	Active	Passed	63	118	18	86
4/7/2017	Chemistry Building	128	Chemistry	1312	Active	Passed	63	112	18	86
4/7/2017	Chemistry Building	127	Chemistry	1288	Active	Passed	64	125	18	86
4/7/2017	Chemistry Building	127	Chemistry	1291	Active	Passed	62	126	18	86
4/7/2017	Chemistry Building	127	Chemistry	1290	Active	Failed	63	93	18	86
4/7/2017	Chemistry Building	111	Chemistry	1275	Active	Passed	63	83	18	86
4/7/2017	Chemistry Building	127	Chemistry	1289	Active	Passed	62	125	18	86
4/7/2017	Chemistry Building	127	Chemistry	1287	Active	Passed	63	106	18	86
4/7/2017	Chemistry Building	127	Chemistry	1286	Active	Passed	62	125	18	86
4/7/2017	Chemistry Building	127	Chemistry	1285	Active	Passed	61	117	18	86
4/7/2017	Chemistry Building	127	Chemistry	1284	Active	Passed	62	107	18	86
4/7/2017	Chemistry Building	127	Chemistry	1283	Active	Passed	61	109	18	86

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/7/2017	Chemistry Building	127	Chemistry	1282	Active	Passed	62	102	18	86
4/7/2017	Chemistry Building	128	Chemistry	1322	Active	Passed	64	114	18	86
4/7/2017	Chemistry Building	128	Chemistry	1323	Active	Passed	63	108	18	86
4/7/2017	Chemistry Building	127	Chemistry	1281	Active	Passed	62	125	18	86
4/8/2017	Chemistry Building	111	Chemistry	1273	Active	Passed	62	110	18	86
4/8/2017	Chemistry Building	128	Chemistry	1315	Active	Passed	63	93	18	86
4/10/2017	Chemistry Building	417A	Chemistry	1447	Active	Failed	65	160	18	62
4/10/2017	Chemistry Building	427A	Chemistry	1438	Active	Passed	61	84	18	62
4/10/2017	Chemistry Building	417A	Chemistry	1445	Active	Failed	65	155	18	62
4/10/2017	Chemistry Building	428A	Chemistry	1431	Active	Failed	62	80	18	62
4/10/2017	Chemistry Building	424A	Chemistry	1430	Active	Failed	64	175	20	62
4/10/2017	Chemistry Building	418A	Chemistry	1425	Active	Failed	62	92	18	62
4/10/2017	Chemistry Building	422A	Chemistry	1427	Active	Failed	61	109	18	62
4/10/2017	Chemistry Building	428A	Chemistry	1433	Active	Failed	60	90	18	62
4/10/2017	Chemistry Building	428A	Chemistry	1434	Active	Failed	61	111	18	62
4/10/2017	Chemistry Building	414A	Chemistry	1421	Active	Passed	59	113	18	62
4/10/2017	Chemistry Building	413A	Chemistry	1448	Active	Failed	64	199	18	62
4/10/2017	Chemistry Building	412A	Chemistry	1417	Active	Failed	61	120	18	62
4/10/2017	Chemistry Building	421A	Chemistry	1443	Active	Failed	64	141	18	62
4/10/2017	Chemistry Building	412A	Chemistry	1418	Active	Passed	60	88	18	62
4/10/2017	Chemistry Building	412A	Chemistry	1419	Active	Failed	62	108	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/10/2017	Chemistry Building	417A	Chemistry	1446	Active	Failed	64	100	18	62
4/10/2017	Chemistry Building	411A	Chemistry	1452	Active	Failed	61	128	18	62
4/10/2017	Chemistry Building	418A	Chemistry	1424	Active	Failed	60	152	18	62
4/10/2017	Chemistry Building	405B	Chemistry	1416	Active	Passed	65	82	18	50
4/10/2017	Chemistry Building	418A	Chemistry	1423	Active	Passed	62	110	18	62
4/10/2017	Chemistry Building	427A	Chemistry	1436	Active	Failed	63	149	18	62
4/10/2017	Chemistry Building	418A	Chemistry	1422	Active	Failed	61	117	18	62
4/10/2017	Chemistry Building	421A	Chemistry	1442	Active	Failed	65	154	18	62
4/10/2017	Chemistry Building	423A	Chemistry	1439	Active	Passed	61	98	18	62
4/10/2017	Chemistry Building	422A	Chemistry	1429	Active	Failed	62	90	18	62
4/10/2017	Chemistry Building	427A	Chemistry	1435	Active	Passed	62	122	18	62
4/10/2017	Chemistry Building	411A	Chemistry	1451	Active	Failed	60	153	18	62
4/10/2017	Chemistry Building	411A	Chemistry	1450	Active	Failed	63	114	18	62
4/10/2017	Chemistry Building	427A	Chemistry	1437	Active	Failed	61	136	18	62
4/10/2017	Chemistry Building	417A	Chemistry	1444	Active	Passed	60	101	18	62
4/10/2017	Chemistry Building	411A	Chemistry	1449	Active	Failed	62	89	18	62
4/10/2017	Chemistry Building	422A	Chemistry	1428	Active	Failed	62	105	18	62
4/10/2017	Chemistry Building	422A	Chemistry	1426	Active	Failed	63	107	18	62
4/10/2017	Chemistry Building	421A	Chemistry	1441	Active	Failed	62	120	18	62
4/11/2017	Chemistry Building	305B	Chemistry	1377	Active	Passed	67	120	26	50
4/11/2017	Chemistry Building	322A	Chemistry	1390	Active	Passed	62	118	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/11/2017	Chemistry Building	313A	Chemistry	1410	Active	Passed	63	128	18	62
4/11/2017	Chemistry Building	314A	Chemistry	1383	Active	Passed	62	91	18	62
4/11/2017	Chemistry Building	317A	Chemistry	1408	Active	Passed	61	108	18	62
4/11/2017	Chemistry Building	312A	Chemistry	1380	Active	Failed	63	153	18	62
4/11/2017	Chemistry Building	317A	Chemistry	1406	Active	Passed	61	106	18	62
4/11/2017	Chemistry Building	312A	Chemistry	1381	Active	Failed	62	135	18	62
4/11/2017	Chemistry Building	318A	Chemistry	1387	Active	Passed	63	98	18	62
4/11/2017	Chemistry Building	318A	Chemistry	1386	Active	Passed	64	113	18	62
4/11/2017	Chemistry Building	318A	Chemistry	1385	Active	Passed	62	98	18	62
4/11/2017	Chemistry Building	318A	Chemistry	1384	Active	Passed	63	91	18	62
4/11/2017	Chemistry Building	321A	Chemistry	1403	Active	Passed	61	96	18	62
4/11/2017	Chemistry Building	321A	Chemistry	1402	Active	Failed	62	109	18	62
4/11/2017	Chemistry Building	312A	Chemistry	1379	Active	Failed	61	133	18	62
4/11/2017	Chemistry Building	327A	Chemistry	1397	Active	Passed	62	97	18	62
4/11/2017	Chemistry Building	322A	Chemistry	1389	Active	Passed	62	97	18	62
4/11/2017	Chemistry Building	322A	Chemistry	1388	Active	Passed	61	85	18	62
4/11/2017	Chemistry Building	323A	Chemistry	1401	Active	Passed	59	132	18	62
4/11/2017	Chemistry Building	324A	Chemistry	1392	Active	Passed	63	85	18	62
4/11/2017	Chemistry Building	327A	Chemistry	1400	Active	Passed	63	84	18	62
4/11/2017	Chemistry Building	322A	Chemistry	1391	Active	Failed	62	101	18	62
4/11/2017	Chemistry Building	327A	Chemistry	1398	Active	Passed	63	102	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/11/2017	Chemistry Building	305B	Chemistry	1378	Active	Passed	68	103	20	50
4/11/2017	Chemistry Building	328A	Chemistry	1396	Active	Passed	62	86	18	62
4/11/2017	Chemistry Building	328A	Chemistry	1395	Active	Failed	63	117	18	62
4/11/2017	Chemistry Building	328A	Chemistry	1394	Active	Passed	63	86	18	62
4/11/2017	Chemistry Building	328A	Chemistry	1393	Active	Passed	62	84	18	62
4/11/2017	Chemistry Building	312A	Chemistry	1382	Active	Failed	64	123	18	62
4/11/2017	Chemistry Building	317A	Chemistry	1409	Active	Passed	63	88	18	62
4/11/2017	Chemistry Building	327A	Chemistry	1399	Active	Failed	63	100	18	62
4/11/2017	Chemistry Building	317A	Chemistry	1407	Active	Failed	62	121	18	62
4/12/2017	Chemistry Building	G022	Chemistry	1329	Active	Failed	60	114	18	50
4/12/2017	Chemistry Building	G021	Chemistry	1336	Active	Passed	60	107	18	50
4/12/2017	Chemistry Building	228A	Chemistry	1355	Active	Failed	63	114	18	62
4/12/2017	Chemistry Building	228A	Chemistry	1356	Active	Failed	63	106	18	62
4/12/2017	Chemistry Building	228A	Chemistry	1357	Active	Failed	63	96	18	62
4/12/2017	Chemistry Building	G003	Chemistry	1454	Active	Passed	61	129	19	50
4/12/2017	Chemistry Building	G006	Chemistry	1326	Active	Passed	59	129	18	50
4/12/2017	Chemistry Building	G011	Chemistry	1338	Active	Failed	61	92	18	50
4/12/2017	Chemistry Building	G012A	Chemistry	1327	Active	Failed	60	100	18	50
4/12/2017	Chemistry Building	228A	Chemistry	1358	Active	Passed	64	92	18	62
4/12/2017	Chemistry Building	217A	Chemistry	1370	Active	Failed	64	102	18	62
4/12/2017	Chemistry Building	217A	Chemistry	1371	Active	Passed	63	99	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/12/2017	Chemistry Building	227A	Chemistry	1360	Active	Passed	63	103	18	62
4/12/2017	Chemistry Building	G017	Chemistry	1337	Active	Failed	61	92	18	62
4/12/2017	Chemistry Building	G002	Chemistry	1325	Active	Failed	65	132	18	50
4/12/2017	Chemistry Building	G018	Chemistry	1330	Active	Failed	61	80	18	50
4/12/2017	Chemistry Building	222A	Chemistry	1353	Active	Passed	63	119	18	62
4/12/2017	Chemistry Building	222A	Chemistry	1352	Active	Failed	62	118	18	62
4/12/2017	Chemistry Building	222A	Chemistry	1351	Active	Passed	62	105	18	62
4/12/2017	Chemistry Building	222A	Chemistry	1350	Active	Passed	61	109	18	62
4/12/2017	Chemistry Building	223A	Chemistry	1363	Active	Passed	62	147	18	62
4/12/2017	Chemistry Building	224A	Chemistry	1354	Active	Passed	67	106	24	62
4/12/2017	Chemistry Building	227A	Chemistry	1359	Active	Passed	62	134	18	62
4/12/2017	Chemistry Building	217A	Chemistry	1368	Active	Passed	67	95	18	62
4/12/2017	Chemistry Building	227A	Chemistry	1362	Active	Passed	63	111	18	62
4/12/2017	Chemistry Building	217A	Chemistry	1369	Active	Failed	65	107	18	62
4/12/2017	Chemistry Building	227A	Chemistry	1361	Active	Failed	64	124	18	62
4/12/2017	Chemistry Building	G014	Chemistry	1328	Active	Failed	60	119	18	50
4/12/2017	Chemistry Building	221A	Chemistry	1364	Active	Passed	62	102	18	62
4/12/2017	Chemistry Building	218A	Chemistry	1348	Active	Passed	62	84	18	62
4/12/2017	Chemistry Building	213A	Chemistry	1372	Active	Passed	62	148	18	62
4/12/2017	Chemistry Building	218A	Chemistry	1347	Active	Passed	61	81	18	62
4/12/2017	Chemistry Building	G028	Chemistry	1332	Active	Failed	63	123	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/12/2017	Chemistry Building	211A	Chemistry	1376	Active	Passed	63	86	18	62
4/12/2017	Chemistry Building	205B	Chemistry	1339	Active	Passed	65	120	20	50
4/12/2017	Chemistry Building	205B	Chemistry	1340	Active	Passed	67	102	24	50
4/12/2017	Chemistry Building	218A	Chemistry	1346	Active	Passed	63	118	18	62
4/12/2017	Chemistry Building	221A	Chemistry	1367	Active	Passed	61	88	18	62
4/12/2017	Chemistry Building	212A	Chemistry	1342	Active	Passed	62	104	18	62
4/12/2017	Chemistry Building	221A	Chemistry	1366	Active	Failed	63	119	18	62
4/12/2017	Chemistry Building	G024	Chemistry	1331	Active	Passed	61	83	18	50
4/12/2017	Chemistry Building	218A	Chemistry	1349	Active	Passed	63	89	18	62
4/12/2017	Chemistry Building	G055	Chemistry	1333	Active	Passed	64	113	18	50
4/12/2017	Chemistry Building	G027	Chemistry	1335	Active	Failed	59	85	18	50
4/12/2017	Chemistry Building	G045	Chemistry	1334	Active	Passed	58	95	18	50
4/12/2017	Chemistry Building	214A	Chemistry	1345	Active	Passed	62	99	18	62
4/12/2017	Chemistry Building	221A	Chemistry	1365	Active	Failed	62	115	18	62
4/12/2017	Chemistry Building	G051	Chemistry	1530	Active	Passed	62	99	18	50
4/12/2017	Chemistry Building	G003	Chemistry	1455	Active	Passed	60	118	19	50
4/12/2017	Chemistry Building	211A	Chemistry	1375	Active	Passed	61	107	18	62
4/12/2017	Chemistry Building	211A	Chemistry	1374	Active	Passed	62	106	18	62
4/12/2017	Chemistry Building	211A	Chemistry	1373	Active	Failed	60	120	18	62
4/12/2017	Chemistry Building	212A	Chemistry	1341	Active	Passed	60	79	18	62
4/12/2017	Chemistry Building	212A	Chemistry	1343	Active	Passed	61	84	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
4/13/2017	Chemistry Building	421A	Chemistry	1440	Active	Failed	67	153	18	62
5/3/2017	Chemistry Building	428A	Chemistry	1432	Active	Failed	60	111	18	62
8/17/2017	Chemistry Building	212A	Chemistry	1344	Active	Failed	68	90	18	62
10/16/2017	Chemistry Building	311A	Chemistry	1414	Active	Failed	66	129	18	62
10/16/2017	Chemistry Building	405B	Chemistry	1415	Active	Failed	67	104	18	50
10/16/2017	Chemistry Building	311A	Chemistry	1412	Active	Failed	67	110	18	62
10/16/2017	Chemistry Building	311A	Chemistry	1413	Active	Failed	65	98	18	62
10/17/2017	Chemistry Building	412A	Chemistry	1420	Active	Failed	66	99	18	62
10/31/2017	Chemistry Building	112	Chemistry	1304	Active	Failed	65	154	21	86
4/4/2017	CHEMISTRY LIBRARY	156A	Chemistry	997	Active	Passed	71	100	28	38
4/4/2017	CHEMISTRY LIBRARY	140	Chemistry	996	Active	Passed	68	105	28	38
4/4/2017	CHEMISTRY LIBRARY	121	Chemistry	1057	Active	Passed	62	128	18	38
2/2/2018	DENNY HALL	456A	Anthropology	2547	Active	Passed	58	73	18	63
8/29/2017	Douglas Research Cons.	112J	Urban Horticulture Division	1112	Active	Passed	69	90	18	38
11/29/2017	Douglas Research Cons.	112K	Urban Horticulture Division	1115	Inactive	Passed	0	0	0	38
10/2/2017	ELECTRICAL ENG BLDG	415	Electrical Engineering	1142	Active	Passed	60	104	18	
11/29/2017	ELECTRICAL ENG BLDG	059A	Electrical Engineering	1592	Active	Passed	62	94	18	62
11/29/2017	ELECTRICAL ENG BLDG	B039A	Electrical Engineering	1605	Active	Passed	61	100	28	62
11/29/2017	ELECTRICAL ENG BLDG	B023B	Electrical Engineering	1593	Active	Passed	64	111	28	62
11/29/2017	ELECTRICAL ENG BLDG	B023A	Electrical Engineering	1594	Active	Passed	64	118	28	62
11/29/2017	ELECTRICAL ENG BLDG	B029A	Electrical Engineering	1596	Active	Passed	62	106	28	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/29/2017	ELECTRICAL ENG BLDG	B052A	Electrical Engineering	1599	Active	Passed	64	109	28	62
11/29/2017	ELECTRICAL ENG BLDG	B042A	Electrical Engineering	1600	Active	Passed	62	98	29	62
11/29/2017	ELECTRICAL ENG BLDG	B037A	Electrical Engineering	1604	Active	Passed	63	122	28	62
11/29/2017	ELECTRICAL ENG BLDG	B031A	Electrical Engineering	1598	Active	Passed	62	99	28	62
11/29/2017	ELECTRICAL ENG BLDG	B030	Electrical Engineering	1597	Active	Passed	61	100	29	62
11/29/2017	ELECTRICAL ENG BLDG	B024A	Electrical Engineering	1603	Active	Passed	60	111	18	62
11/29/2017	ELECTRICAL ENG BLDG	065	Electrical Engineering	1855	Active	Passed	64	94	18	62
11/29/2017	ELECTRICAL ENG BLDG	B023A	Electrical Engineering	1595	Active	Passed	65	112	28	62
8/29/2017	ENGINEERING ANNEX	222A	Bioengineering	44	Active	Passed	68	90	18	60
8/29/2017	ENGINEERING ANNEX	215	Mechanical Engineering	1161	Active	Passed	67	135	18	60
8/16/2017	ENVIRON STOR BLDG	105	Environmental Health and Safety	1087	Active	Passed	72	105	18	62
8/16/2017	ENVIRON STOR BLDG	105	Environmental Health and Safety	2258	Active	Passed	68	97	18	87
8/16/2017	ENVIRON STOR BLDG	108	Environmental Health and Safety	2259	Active	Passed	67	83	18	87
8/16/2017	ENVIRON STOR BLDG	104	Environmental Health and Safety	1086	Active	Passed	69	108	18	62
9/26/2017	Fisheries Teach/Research	209	School of Fisheries	1064	Active	Failed	67	182	18	52
9/26/2017	Fisheries Teach/Research	229	School of Fisheries	1531	Active	Failed	64	151	18	52
9/26/2017	Fisheries Teach/Research	213	School of Fisheries	1820	Active	Failed	65	194	18	52
9/26/2017	Fisheries Teach/Research	224	School of Fisheries	1065	Active	Failed	68	177	18	52
9/26/2017	Fisheries Teach/Research	228	School of Fisheries	1066	Active	Failed	68	152	18	52
9/26/2017	Fisheries Teach/Research	125	School of Fisheries	1062	Active	Failed	67	160	18	52
9/26/2017	Fisheries Teach/Research	113	School of Fisheries	1061	Active	Passed	68	144	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/26/2017	Fisheries Teach/Research	124	School of Fisheries	1076	Active	Failed	67	151	18	52
9/26/2017	Fisheries Teach/Research	225	School of Fisheries	1067	Active	Failed	67	177	18	64
11/30/2017	FISHERY SCIENCES	132	School of Fisheries	1675	Active	Passed	63	116	18	62
11/30/2017	FISHERY SCIENCES	348	School of Fisheries	1693	Active	Passed	64	94	18	62
11/30/2017	FISHERY SCIENCES	139	School of Fisheries	1677	Active	Passed	65	90	18	62
11/30/2017	FISHERY SCIENCES	142	School of Fisheries	1680	Active	Passed	65	110	18	38
11/30/2017	FISHERY SCIENCES	142	School of Fisheries	1679	Active	Passed	65	95	18	38
11/30/2017	FISHERY SCIENCES	142	School of Fisheries	1678	Active	Passed	64	105	18	38
11/30/2017	FISHERY SCIENCES	146A	School of Fisheries	1682	Active	Passed	66	115	18	68
11/30/2017	FISHERY SCIENCES	142	School of Fisheries	1681	Active	Passed	64	100	18	68
11/30/2017	FISHERY SCIENCES	138	School of Fisheries	1676	Active	Passed	63	111	18	62
11/30/2017	FISHERY SCIENCES	346	School of Fisheries	1692	Active	Passed	60	109	18	62
11/30/2017	FISHERY SCIENCES	248	School of Fisheries	1687	Active	Passed	63	102	18	68
11/30/2017	FISHERY SCIENCES	246	School of Fisheries	1686	Active	Passed	65	106	18	68
11/30/2017	FISHERY SCIENCES	242	School of Fisheries	1685	Active	Passed	66	106	18	68
11/30/2017	FISHERY SCIENCES	236	School of Fisheries	1684	Active	Passed	64	100	18	68
11/30/2017	FISHERY SCIENCES	232	School of Fisheries	1683	Active	Passed	65	113	18	68
11/30/2017	FISHERY SCIENCES	332	School of Fisheries	1688	Active	Passed	64	99	18	62
11/30/2017	FISHERY SCIENCES	334	School of Fisheries	1689	Active	Passed	63	101	18	68
11/30/2017	FISHERY SCIENCES	340	School of Fisheries	1690	Active	Passed	63	100	18	68
11/30/2017	FISHERY SCIENCES	342	School of Fisheries	1691	Active	Passed	62	111	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/23/2017	FLUKE HALL	235	Molecular Biotechnology	1743	Active	Passed	60	110	18	88
8/23/2017	FLUKE HALL	225	Molecular Biotechnology	1143	Active	Passed	58	111	18	38
10/2/2017	FLUKE HALL	225	Molecular Biotechnology	1145	Active	Passed	60	109	18	50
10/2/2017	FLUKE HALL	225	Molecular Biotechnology	1144	Active	Passed	60	113	18	38
10/2/2017	FLUKE HALL	225	Molecular Biotechnology	1146	Active	Passed	64	91	18	50
10/2/2017	FLUKE HALL	225	Molecular Biotechnology	1147	Active	Passed	64	91	18	50
10/2/2017	FLUKE HALL	225	Molecular Biotechnology	1148	Active	Passed	62	98	18	38
10/2/2017	FLUKE HALL	239B	Molecular Biotechnology	1150	Active	Passed	61	86	18	50
10/2/2017	FLUKE HALL	235	Molecular Biotechnology	1149	Active	Passed	59	115	18	38
5/31/2017	FOEGE BUILDING	N351C	Bioengineering	1972	Active	Passed	63	111	18	52
6/5/2017	FOEGE BUILDING	N409C	Bioengineering	1968	Active	Passed	60	116	18	50
6/5/2017	FOEGE BUILDING	N351A	Bioengineering	1971	Active	Passed	60	92	18	52
6/5/2017	FOEGE BUILDING	N415A	Bioengineering	1969	Active	Passed	62	113	18	52
6/5/2017	FOEGE BUILDING	N415A	Bioengineering	1970	Active	Passed	62	106	18	63
6/5/2017	FOEGE BUILDING	N333C	Bioengineering	1974	Active	Passed	61	109	18	52
6/5/2017	FOEGE BUILDING	N509C	Bioengineering	1957	Active	Passed	60	120	18	52
6/5/2017	FOEGE BUILDING	N323C	Bioengineering	1978	Active	Passed	60	125	18	52
6/5/2017	FOEGE BUILDING	N333C	Bioengineering	1975	Active	Passed	60	105	18	52
6/5/2017	FOEGE BUILDING	N551B	Bioengineering	1953	Active	Passed	61	117	18	52
6/5/2017	FOEGE BUILDING	N551A	Bioengineering	1954	Active	Passed	62	111	18	52
6/5/2017	FOEGE BUILDING	N533C	Bioengineering	1955	Active	Passed	61	118	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/5/2017	FOEGE BUILDING	N523	Bioengineering	1958	Active	Passed	62	116	18	52
6/5/2017	FOEGE BUILDING	N523-C	Bioengineering	1959	Active	Passed	62	125	18	52
6/5/2017	FOEGE BUILDING	N423C	Bioengineering	1964	Active	Passed	62	131	18	86
6/5/2017	FOEGE BUILDING	N509C	Bioengineering	1960	Active	Passed	59	99	18	52
6/5/2017	FOEGE BUILDING	N451A	Bioengineering	1967	Active	Passed	58	126	18	52
6/5/2017	FOEGE BUILDING	N509 B	Bioengineering	1962	Active	Passed	61	121	18	52
6/5/2017	FOEGE BUILDING	N509 B	Bioengineering	1963	Active	Passed	62	112	18	52
6/5/2017	FOEGE BUILDING	N451A	Bioengineering	1966	Active	Passed	60	88	18	52
6/5/2017	FOEGE BUILDING	N433C	Bioengineering	1965	Active	Passed	60	99	18	86
6/5/2017	FOEGE BUILDING	N561	Bioengineering	1952	Active	Passed	60	118	18	52
6/5/2017	FOEGE BUILDING	N209C	Bioengineering	1986	Active	Passed	64	131	18	52
6/5/2017	FOEGE BUILDING	N323C	Bioengineering	1976	Active	Passed	61	116	18	52
6/5/2017	FOEGE BUILDING	N333B	Bioengineering	1973	Active	Passed	63	119	18	50
6/5/2017	FOEGE BUILDING	N127N	Bioengineering	1991	Active	Passed	60	109	18	52
6/5/2017	FOEGE BUILDING	N161 D	Bioengineering	1993	Active	Passed	59	110	18	52
6/5/2017	FOEGE BUILDING	N215A	Bioengineering	1985	Active	Passed	61	114	18	52
6/5/2017	FOEGE BUILDING	N223C	Bioengineering	1987	Active	Passed	62	95	18	52
6/5/2017	FOEGE BUILDING	N227C	Bioengineering	1988	Active	Passed	63	108	18	52
6/5/2017	FOEGE BUILDING	N251D	Bioengineering	1989	Active	Passed	60	103	18	52
6/5/2017	FOEGE BUILDING	N309B	Bioengineering	1984	Active	Passed	61	136	23	52
6/5/2017	FOEGE BUILDING	N323C	Bioengineering	1981	Active	Passed	60	99	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/5/2017	FOEGE BUILDING	N323C	Bioengineering	1980	Active	Passed	59	123	18	52
6/5/2017	FOEGE BUILDING	N323C	Bioengineering	1979	Active	Passed	61	121	18	52
6/5/2017	FOEGE BUILDING	N323C	Bioengineering	1977	Active	Failed	60	100	18	52
6/5/2017	FOEGE BUILDING	N323D	Bioengineering	1983	Active	Passed	64	83	18	52
6/5/2017	FOEGE BUILDING	N261	Bioengineering	1990	Active	Passed	62	123	18	52
6/5/2017	FOEGE BUILDING	N151	Bioengineering	1992	Active	Passed	61	118	18	52
6/6/2017	FOEGE BUILDING	S 051	Genome Sciences	2027	Active	Passed	65	106	18	62
6/6/2017	FOEGE BUILDING	S 021	Genome Sciences	2024	Active	Passed	64	101	18	62
6/6/2017	FOEGE BUILDING	S 220A	Genome Sciences	2036	Active	Failed	67	136	18	62
6/6/2017	FOEGE BUILDING	S 213	Genome Sciences	2033	Active	Passed	65	106	18	62
6/6/2017	FOEGE BUILDING	S 210B	Genome Sciences	2037	Active	Passed	66	122	18	62
6/6/2017	FOEGE BUILDING	S 203	Genome Sciences	2032	Active	Passed	65	116	18	62
6/6/2017	FOEGE BUILDING	S 143	Genome Sciences	2031	Active	Passed	65	112	18	62
6/6/2017	FOEGE BUILDING	S 133	Genome Sciences	2030	Active	Passed	66	115	18	62
6/6/2017	FOEGE BUILDING	S 103	Genome Sciences	2028	Active	Passed	67	118	18	62
6/6/2017	FOEGE BUILDING	S 041	Genome Sciences	2026	Active	Passed	66	106	18	62
6/6/2017	FOEGE BUILDING	S 031	Genome Sciences	2025	Active	Passed	65	100	18	62
6/6/2017	FOEGE BUILDING	S 233	Genome Sciences	2034	Active	Passed	66	117	18	62
6/6/2017	FOEGE BUILDING	S 320A	Genome Sciences	2042	Active	Passed	67	115	18	62
6/6/2017	FOEGE BUILDING	S 113	Genome Sciences	2029	Active	Passed	66	103	18	62
6/6/2017	FOEGE BUILDING	S 343	Genome Sciences	2041	Active	Passed	64	110	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/6/2017	FOEGE BUILDING	S 303	Genome Sciences	2038	Active	Passed	66	120	18	62
6/6/2017	FOEGE BUILDING	S 313	Genome Sciences	2039	Active	Passed	68	123	18	62
6/6/2017	FOEGE BUILDING	S 443	Genome Sciences	2047	Active	Passed	67	115	18	62
6/6/2017	FOEGE BUILDING	S 433	Genome Sciences	2046	Active	Passed	66	114	18	62
6/6/2017	FOEGE BUILDING	S 420A	Genome Sciences	2048	Active	Passed	65	111	18	62
6/6/2017	FOEGE BUILDING	S 410B	Genome Sciences	2049	Active	Passed	67	121	18	62
6/6/2017	FOEGE BUILDING	S 413	Genome Sciences	2045	Active	Passed	67	116	18	62
6/6/2017	FOEGE BUILDING	S 403	Genome Sciences	2044	Active	Passed	69	102	18	62
6/6/2017	FOEGE BUILDING	S 333	Genome Sciences	2040	Active	Passed	68	122	18	62
6/6/2017	FOEGE BUILDING	S 310B	Genome Sciences	2043	Active	Passed	67	118	18	62
6/14/2017	FOEGE BUILDING	N557	Bioengineering	1951	Active	Passed	59	116	18	52
6/15/2017	FOEGE BUILDING	N509 B	Bioengineering	1961	Active	Passed	61	108	18	52
6/15/2017	FOEGE BUILDING	N323D	Bioengineering	1982	Active	Passed	63	115	18	86
7/7/2017	FOEGE BUILDING	S 243	Genome Sciences	2035	Active	Passed	67	107	18	62
2/24/2017	FRI HRB LAB 01	LAB 7	Biology Program	2220	Active	Passed	63	77	18	36
2/24/2017	FRI HRB LAB 01	lower lab	Biology Program	1619	Active	Passed	67	131	18	36
2/24/2017	FRI HRB LAB 01	10 lower	Biology Program	1835	Active	Passed	57	104	18	40
2/24/2017	FRI HRB LAB 01	10-upper	Biology Program	1836	Active	Passed	55	115	18	40
2/24/2017	FRI HRB LAB 01	806	Biology Program	1620	Active	Passed	60	88	18	48
2/24/2017	FRI HRB LAB 01	AIN LAB BSMN	Biology Program	1618	Active	Passed	77	89	18	48
8/29/2017	GUGGENHEIM HALL	107	Aeronautics and Astronautics	2216	Active	Passed	71	94	18	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
3/22/2017	GUTHRIE HALL	401	Psychology	567	Active	Passed	67	107	26	38
6/5/2017	GUTHRIE HALL	354A	Psychology	2536	Active	Passed	68	110	18	63
6/5/2017	GUTHRIE HALL	414	Psychology	2540	Active	Passed	68	111	18	38
6/5/2017	GUTHRIE HALL	361	Psychology	2539	Active	Passed	68	100	18	63
6/5/2017	GUTHRIE HALL	401	Psychology	2541	Active	Passed	68	109	27	44
6/5/2017	GUTHRIE HALL	361	Psychology	2538	Active	Passed	68	100	18	63
6/5/2017	GUTHRIE HALL	360	Psychology	2537	Active	Passed	68	105	18	63
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1579	Active	Passed	64	133	18	84
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1575	Active	Passed	64	111	18	84
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1576	Active	Passed	65	100	18	84
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1578	Active	Passed	66	119	23	84
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1580	Active	Passed	62	115	21	84
5/31/2017	HARBORVIEW MED CNTR	1WC-518	Radiation Oncology	1586	Active	Passed	64	78	18	38
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1581	Active	Passed	18	111	58	38
5/31/2017	HARBORVIEW MED CNTR	GWH-47	Laboratory Medicine	1577	Active	Passed	64	139	18	84
10/25/2017	HARBORVIEW MED CNTR	2EC-28	Pathology	1630	Active	Passed	65	109	18	62
5/16/2017	HARBORVIEW NJB	2NJ-269	Pathology	2167	Active	Passed	64	95	18	52
5/30/2017	HARBORVIEW NJB	3NJ-324	School of Medicine	2183	Active	Passed	67	132	18	40
5/30/2017	HARBORVIEW NJB	2NJ-270	Pathology	2172	Active	Failed	64	95	18	64
5/30/2017	HARBORVIEW NJB	2NJ-274	Pathology	2174	Active	Passed	62	86	18	64
5/30/2017	HARBORVIEW NJB	3NJ-342.1	School of Medicine	2181	Active	Passed	65	86	18	64

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/30/2017	HARBORVIEW NJB	3NJ-317.8	School of Medicine	2180	Active	Passed	66	91	18	64
5/30/2017	HARBORVIEW NJB	3NJ-317.6	School of Medicine	2179	Active	Passed	67	86	18	64
5/30/2017	HARBORVIEW NJB	3NJ-317.2	School of Medicine	2178	Active	Passed	68	85	18	64
5/30/2017	HARBORVIEW NJB	2NJ-274	Pathology	2173	Active	Passed	63	98	18	64
5/30/2017	HARBORVIEW NJB	2NJ-270	Pathology	2171	Active	Passed	63	92	18	64
5/30/2017	HARBORVIEW NJB	2NJ-272.1	Pathology	2170	Active	Passed	64	92	18	64
5/30/2017	HARBORVIEW NJB	2NJ-272	Pathology	2169	Active	Passed	65	102	18	40
5/30/2017	HARBORVIEW NJB	3NJ-342.6	School of Medicine	2182	Active	Passed	62	84	18	64
5/30/2017	HARBORVIEW NJB	2NJ-274	Pathology	2175	Active	Passed	63	86	18	64
5/30/2017	HARBORVIEW NJB	2NJ-272	Pathology	2168	Active	Passed	63	89	18	64
10/7/2017	HARBORVIEW R&T	620E	Harborview Medical Center	1643	Active	Passed	67	149	18	38
10/17/2017	HARBORVIEW R&T	710	Harborview Medical Center	1674	Active	Failed	61	111	18	62
10/17/2017	HARBORVIEW R&T	713	Harborview Medical Center	1639	Active	Passed	60	116	18	62
10/17/2017	HARBORVIEW R&T	626	Harborview Medical Center	1642	Active	Failed	61	99	18	62
10/17/2017	HARBORVIEW R&T	618	Harborview Medical Center	1641	Active	Passed	62	95	18	62
10/17/2017	HARBORVIEW R&T	613	Harborview Medical Center	1644	Active	Passed	62	109	18	62
10/17/2017	HARBORVIEW R&T	621	Harborview Medical Center	1645	Active	Passed	61	88	18	62
10/17/2017	HARBORVIEW R&T	627	Harborview Medical Center	1646	Active	Passed	61	94	18	62
10/17/2017	HARBORVIEW R&T	718	Harborview Medical Center	1637	Active	Failed	61	96	18	62
10/17/2017	HARBORVIEW R&T	726	Harborview Medical Center	1638	Active	Passed	60	87	18	62
10/17/2017	HARBORVIEW R&T	610	Harborview Medical Center	1640	Active	Passed	62	110	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/17/2017	HARBORVIEW R&T	715A	Medicine	1819	Active	Failed	64	185	18	40
10/18/2017	HARBORVIEW R&T	418	Harborview Medical Center	1654	Active	Passed	64	117	18	62
10/18/2017	HARBORVIEW R&T	513	Harborview Medical Center	1652	Active	Passed	63	120	18	62
10/18/2017	HARBORVIEW R&T	510	Harborview Medical Center	1647	Active	Passed	62	99	18	62
10/18/2017	HARBORVIEW R&T	518	Harborview Medical Center	1648	Active	Passed	65	102	18	62
10/18/2017	HARBORVIEW R&T	526	Harborview Medical Center	1649	Active	Passed	63	107	18	62
10/18/2017	HARBORVIEW R&T	521	Harborview Medical Center	1651	Active	Passed	63	96	18	62
10/18/2017	HARBORVIEW R&T	527	Harborview Medical Center	1650	Active	Passed	64	86	18	62
10/18/2017	HARBORVIEW R&T	410	Harborview Medical Center	1653	Active	Passed	62	90	18	62
10/18/2017	HARBORVIEW R&T	426	Harborview Medical Center	1655	Active	Passed	63	114	18	62
10/18/2017	HARBORVIEW R&T	413	Harborview Medical Center	1659	Active	Passed	63	85	18	62
10/18/2017	HARBORVIEW R&T	420E	Harborview Medical Center	1656	Active	Passed	63	117	18	62
10/18/2017	HARBORVIEW R&T	326	Harborview Medical Center	1660	Active	Passed	63	105	18	62
10/18/2017	HARBORVIEW R&T	313	Harborview Medical Center	1663	Active	Passed	62	106	18	62
10/18/2017	HARBORVIEW R&T	312	Harborview Medical Center	1664	Active	Passed	63	127	18	62
10/18/2017	HARBORVIEW R&T	427	Harborview Medical Center	1657	Active	Failed	64	102	18	62
10/18/2017	HARBORVIEW R&T	421	Harborview Medical Center	1658	Active	Passed	63	102	18	62
10/24/2017	HARBORVIEW R&T	SB011	Harborview Medical Center	1672	Active	Passed	64	147	18	38
10/24/2017	HARBORVIEW R&T	327	Harborview Medical Center	1661	Active	Passed	63	121	18	62
10/24/2017	HARBORVIEW R&T	B018	Comparative Medicine	1817	Active	Passed	68	102	18	40
10/24/2017	HARBORVIEW R&T	B018	Comparative Medicine	1816	Active	Passed	65	111	18	40

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/24/2017	HARBORVIEW R&T	B016	Harborview Medical Center	1667	Active	Passed	62	122	18	38
10/24/2017	HARBORVIEW R&T	B008	Pathology	2055	Active	Passed	63	97	18	62
10/24/2017	HARBORVIEW R&T	B004	Harborview Medical Center	1665	Active	Failed	61	157	18	38
10/24/2017	HARBORVIEW R&T	B010	Harborview Medical Center	1666	Active	Failed	64	167	18	38
10/24/2017	HARBORVIEW R&T	SB044	Comparative Medicine	1668	Active	Failed	65	179	18	38
10/24/2017	HARBORVIEW R&T	SB049	Comparative Medicine	1669	Active	Failed	68	152	18	38
10/24/2017	HARBORVIEW R&T	SB011	Comparative Medicine	1673	Active	Passed	66	148	18	38
10/24/2017	HARBORVIEW R&T	SB011	Comparative Medicine	1671	Active	Failed	65	152	18	38
10/24/2017	HARBORVIEW R&T	SB023	Harborview Medical Center	1670	Active	Failed	64	156	18	38
12/12/2017	HARBORVIEW R&T	321	Harborview Medical Center	1662	Active	Passed	62	110	18	62
12/12/2017	HENDERSON HALL (APL)	HH 301D	Applied Physics Laboratory	1915	Active	Passed	64	136	18	40
11/28/2017	HITCHCOCK HALL	407	Biology Program	928	Active	Passed	64	101	27	48
11/28/2017	HITCHCOCK HALL	105	Biology Program	925	Active	Passed	60	102	27	48
11/28/2017	HITCHCOCK HALL	123	Biology Program	678	Active	Passed	63	109	27	48
11/28/2017	HITCHCOCK HALL	143A	Biology Program	680	Active	Passed	63	109	27	48
11/28/2017	HITCHCOCK HALL	144A	Biology Program	681	Active	Passed	65	120	27	48
11/28/2017	HITCHCOCK HALL	218	Biology Program	682	Active	Passed	73	140	28	48
11/28/2017	HITCHCOCK HALL	243A	Biology Program	684	Active	Passed	72	141	28	48
11/28/2017	HITCHCOCK HALL	244A	Biology Program	686	Active	Passed	68	121	27	48
11/28/2017	HITCHCOCK HALL	307	Biology Program	687	Active	Passed	69	122	18	48
11/28/2017	HITCHCOCK HALL	346A	Biology Program	690	Active	Passed	71	122	18	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/28/2017	HITCHCOCK HALL	406	Biology Program	929	Active	Passed	65	113	18	48
11/28/2017	HITCHCOCK HALL	543	Biology Program	700	Active	Passed	74	104	29	58
11/28/2017	HITCHCOCK HALL	413	Biology Program	694	Active	Passed	72	145	27	36
11/28/2017	HITCHCOCK HALL	413	Biology Program	695	Active	Passed	71	111	27	58
11/28/2017	HITCHCOCK HALL	444A	Biology Program	692	Active	Passed	65	87	27	48
11/28/2017	HITCHCOCK HALL	506	Biology Program	696	Active	Passed	69	105	27	48
11/28/2017	HITCHCOCK HALL	522	Biology Program	697	Active	Passed	66	106	18	48
11/28/2017	HITCHCOCK HALL	516	Biology Program	1097	Active	Passed	60	104	27	48
11/28/2017	HITCHCOCK HALL	309	Biology Program	688	Active	Passed	70	116	18	58
11/28/2017	HITCHCOCK HALL	544A	Biology Program	927	Active	Passed	71	106	25	48
11/28/2017	HITCHCOCK HALL	520A	Biology Program	698	Active	Passed	70	84	23	58
11/28/2017	HITCHCOCK HALL	520A	Biology Program	699	Active	Passed	70	85	18	36
11/28/2017	HITCHCOCK HALL	507	Biology Program	926	Active	Passed	74	95	27	58
11/28/2017	HITCHCOCK HALL	523	Biology Program	685	Active	Passed	75	111	24	48
11/28/2017	HITCHCOCK HALL	347A	Biology Program	691	Active	Passed	70	103	28	48
11/29/2017	HITCHCOCK HALL	012	Genetics	218	Active	Passed	66	93	18	60
11/29/2017	HITCHCOCK HALL	302	Biology Program	1118	Inactive	Passed	0	0	0	36
11/29/2017	HITCHCOCK HALL	128	Biology Program	679	Active	Passed	64	100	18	36
11/29/2017	HITCHCOCK HALL	223	Biology Program	821	Inactive	Passed	0	0	0	84
11/29/2017	HITCHCOCK HALL	309	Biology Program	689	Active	Passed	72	140	18	36
12/29/2017	HITCHCOCK HALL	423	Biology Program	931	Active	Passed	64	96	24	58

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/12/2018	HITCHCOCK HALL	014	Biochemistry	219	Active	Passed	63	90	18	60
11/29/2017	JOHNSON HALL	217	Biology Program	1925	Active	Passed	61	92	18	62
11/29/2017	JOHNSON HALL	418	Quaternary Research Center	1948	Active	Passed	60	108	18	62
11/29/2017	JOHNSON HALL	039 A	Earth , Space and Science	1919	Active	Passed	58	81	18	50
11/29/2017	JOHNSON HALL	126	Biology Program	1922	Active	Passed	60	95	18	62
11/29/2017	JOHNSON HALL	203 B	Biology Program	1924	Active	Passed	63	100	18	62
11/29/2017	JOHNSON HALL	117	Earth , Space and Science	1920	Active	Passed	63	112	18	86
11/29/2017	JOHNSON HALL	221	Biology Program	1926	Active	Passed	62	97	18	62
11/29/2017	JOHNSON HALL	226	Earth , Space and Science	1927	Active	Passed	61	114	18	50
11/29/2017	JOHNSON HALL	302 A	Quaternary Research Center	1928	Active	Passed	62	113	18	62
11/29/2017	JOHNSON HALL	303 B	Quaternary Research Center	1932	Active	Passed	61	103	18	62
11/29/2017	JOHNSON HALL	303 B	Quaternary Research Center	1931	Active	Passed	62	109	18	62
11/29/2017	JOHNSON HALL	318	Quaternary Research Center	1934	Active	Passed	65	124	18	50
11/29/2017	JOHNSON HALL	402 A	Quaternary Research Center	1935	Active	Passed	63	120	18	63
11/29/2017	JOHNSON HALL	402 A	Quaternary Research Center	1936	Active	Passed	62	125	18	63
11/29/2017	JOHNSON HALL	403 B	Quaternary Research Center	1939	Active	Passed	61	100	18	86
11/29/2017	JOHNSON HALL	422	Quaternary Research Center	1950	Active	Passed	63	124	18	62
11/29/2017	JOHNSON HALL	422	Quaternary Research Center	1949	Active	Passed	63	117	18	62
11/29/2017	JOHNSON HALL	202 A	Biology Program	1923	Active	Passed	62	93	18	62
11/29/2017	JOHNSON HALL	305 A	Quaternary Research Center	1933	Active	Passed	63	107	18	86
3/29/2017	KANE HALL	118A	Chemistry	790	Active	Passed	64	102	57	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/15/2017	KINCAID HALL	238	Biology Program	624	Active	Passed	60	105	18	36
12/15/2017	KINCAID HALL	340	Biology Program	715	Active	Passed	60	123	18	36
12/15/2017	KINCAID HALL	310	Biology Program	720	Active	Passed	63	119	27	48
12/15/2017	KINCAID HALL	307	Biology Program	719	Active	Passed	63	126	18	36
12/15/2017	KINCAID HALL	302d	Biology Program	716	Active	Passed	64	100	28	36
12/15/2017	KINCAID HALL	256	Biology Program	620	Active	Passed	62	94	29	36
12/15/2017	KINCAID HALL	548	Biology Program	726	Active	Passed	61	108	24	36
12/15/2017	KINCAID HALL	262B	Biology Program	718	Active	Passed	66	104	28	36
12/15/2017	KINCAID HALL	402	Biology Program	1093	Active	Passed	64	102	29	36
12/15/2017	KINCAID HALL	410	Biology Program	454	Active	Passed	63	98	29	36
12/15/2017	KINCAID HALL	416	Biology Program	723	Active	Passed	64	106	28	36
12/15/2017	KINCAID HALL	548A	Biology Program	728	Active	Passed	62	113	24	36
12/15/2017	KINCAID HALL	548	Biology Program	727	Active	Passed	62	127	23	36
12/15/2017	KINCAID HALL	508A	Biology Program	1589	Active	Passed	64	98	27	52
12/15/2017	KINCAID HALL	528	Biology Program	725	Active	Passed	62	125	29	36
12/15/2017	KINCAID HALL	222	Biology Program	623	Active	Passed	62	121	18	36
12/15/2017	KINCAID HALL	438	Biology Program	722	Active	Passed	62	128	28	36
12/15/2017	KINCAID HALL	156A	Biology Program	714	Active	Passed	62	111	23	36
12/15/2017	KINCAID HALL	146	Biology Program	803	Active	Passed	61	99	27	36
12/15/2017	KINCAID HALL	138	Biology Program	804	Active	Passed	62	104	29	36
12/15/2017	KINCAID HALL	128	Biology Program	713	Active	Passed	61	106	22	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/15/2017	KINCAID HALL	124	Biology Program	805	Active	Passed	63	122	28	36
12/15/2017	KINCAID HALL	107	Biology Program	621	Inactive	Passed	0	0	0	36
12/15/2017	KINCAID HALL	038	Biology Program	886	Active	Passed	67	125	22	36
12/15/2017	KINCAID HALL	026	Biology Program	887	Active	Passed	63	116	28	48
12/15/2017	KINCAID HALL	216	Biology Program	622	Active	Passed	62	114	27	36
10/3/2017	Magnuson Health Sciences AA-wing	108	Pathology	182	Active	Passed	67	111	18	60
10/3/2017	Magnuson Health Sciences AA-wing	108	Pathology	181	Active	Passed	68	93	18	60
10/3/2017	Magnuson Health Sciences AA-wing	214B	Laboratory Medicine	191	Active	Passed	67	144	21	48
10/3/2017	Magnuson Health Sciences AA-wing	222	Laboratory Medicine	643	Active	Passed	66	99	18	48
10/3/2017	Magnuson Health Sciences AA-wing	214A	Laboratory Medicine	190	Active	Passed	68	140	18	48
10/3/2017	Magnuson Health Sciences AA-wing	418	Surgery	1045	Inactive	Passed	65	153	18	53
8/17/2017	Magnuson Health Sciences A-wing	505	Medicine	1737	Active	Passed	64	135	22	48
11/17/2017	Magnuson Health Sciences A-wing	508	Medicine	632	Active	Passed	62	100	24	40
1/20/2017	Magnuson Health Sciences BB-wing	532	Metabolism, Endocrinology, and Nutrition, Medicine	1837	Active	Passed	60	100	18	40
10/5/2017	Magnuson Health Sciences BB-wing	532	Metabolism, Endocrinology, and Nutrition, Medicine	1838	Active	Passed	64	116	18	40
10/17/2017	Magnuson Health Sciences BB-wing	1304	Pulmonary and Critical Care	607	Active	Failed	65	154	21	
10/30/2017	Magnuson Health Sciences BB-wing	1202	Medicine	651	Active	Passed	64	113	21	36
10/31/2017	Magnuson Health Sciences BB-wing	250 A	Anatomic Pathology	2164	Active	Passed	59	90	20	50
10/31/2017	Magnuson Health Sciences BB-wing	1009	Orthopaedics	647	Active	Failed	68	180	18	60
10/31/2017	Magnuson Health Sciences BB-wing	1552	Psychiatry and Behavioral Sciences	666	Active	Passed	64	100	18	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/31/2017	Magnuson Health Sciences BB-wing	222	Pathology	1814	Active	Passed	65	102	18	40
10/31/2017	Magnuson Health Sciences BB-wing	531	Genetics	1101	Active	Passed	67	118	28	36
10/31/2017	Magnuson Health Sciences BB-wing	544	Medicine	653	Inactive	Passed	0	0	0	44
10/31/2017	Magnuson Health Sciences BB-wing	550	Metabolism, Endocrinology, and Nutrition, Medicine	1102	Active	Passed	68	129	18	60
10/31/2017	Magnuson Health Sciences BB-wing	612	Obstetrics and Gynecology	1103	Active	Passed	65	102	22	60
10/31/2017	Magnuson Health Sciences BB-wing	628	Obstetrics and Gynecology	1105	Active	Passed	69	123	18	60
10/31/2017	Magnuson Health Sciences BB-wing	632	Obstetrics and Gynecology	932	Active	Passed	60	121	21	38
10/31/2017	Magnuson Health Sciences BB-wing	857A	Neurology	2528	Active	Passed	69	83	18	63
10/31/2017	Magnuson Health Sciences BB-wing	426	Surgery	628	Inactive	Passed	0	0	0	36
10/31/2017	Magnuson Health Sciences BB-wing	1032	Orthopaedics	648	Active	Passed	65	113	18	36
10/31/2017	Magnuson Health Sciences BB-wing	1369	Medicine	467	Active	Passed	70	116	28	36
10/31/2017	Magnuson Health Sciences BB-wing	1556	Psychiatry and Behavioral Sciences	667	Active	Passed	70	123	24	38
10/31/2017	Magnuson Health Sciences BB-wing	1502	Psychiatry and Behavioral Sciences	920	Active	Failed	74	162	29	60
10/31/2017	Magnuson Health Sciences BB-wing	826	Rehabilitation Medicine	1094	Inactive	Passed	0	0	0	64
10/31/2017	Magnuson Health Sciences BB-wing	1402	Medicine	933	Inactive	Passed	75	102	29	60
10/31/2017	Magnuson Health Sciences BB-wing	1052	Orthopaedics	649	Active	Passed	71	119	29	60
10/31/2017	Magnuson Health Sciences BB-wing	1369	Medicine	468	Active	Passed	68	111	24	60
10/31/2017	Magnuson Health Sciences BB-wing	1312	Medicine	459	Active	Passed	68	108	27	60
10/31/2017	Magnuson Health Sciences BB-wing	1132	Otolaryngology/Head and Neck Surgery	874	Active	Passed	65	97	19	60
10/31/2017	Magnuson Health Sciences BB-wing	1132	Otolaryngology/Head and Neck Surgery	875	Active	Passed	67	98	28	36
10/31/2017	Magnuson Health Sciences BB-wing	1130	Urology	650	Active	Passed	70	144	18	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/31/2017	Magnuson Health Sciences BB-wing	1416	Anesthesiology	661	Inactive	Passed	68	82	21	60
11/17/2017	Magnuson Health Sciences BB-wing	1604	Neurology	668	Active	Passed	64	103	26	60
11/17/2017	Magnuson Health Sciences BB-wing	1544	Psychiatry and Behavioral Sciences	665	Active	Passed	60	106	21	60
11/17/2017	Magnuson Health Sciences BB-wing	1304	Pulmonary and Critical Care	458	Active	Passed	60	103	18	36
12/13/2017	Magnuson Health Sciences BB-wing	030	Radiation Oncology	894	Active	Passed	66	126	18	60
11/17/2017	Magnuson Health Sciences B-wing	128	Oral Biology	634	Active	Passed	64	93	19	60
11/17/2017	Magnuson Health Sciences B-wing	149	Oral Biology	635	Active	Passed	60	97	18	51
11/29/2017	Magnuson Health Sciences B-wing	122K	Environmental Health and Safety	1141	Active	Passed	68	100	24	48
1/18/2018	Magnuson Health Sciences C-wing	415	Pathology	2202	Active	Failed	58	70	18	38
1/18/2018	Magnuson Health Sciences C-wing	525	Pathology	754	Active	Passed	62	103	18	41
1/18/2018	Magnuson Health Sciences C-wing	411	Pathology	1048	Active	Passed	60	83	28	38
1/18/2018	Magnuson Health Sciences C-wing	405	Pathology	753	Inactive	Passed	59	128	18	41
1/18/2018	Magnuson Health Sciences C-wing	209L	Medicine	1020	Active	Passed	65	104	28	52
1/18/2018	Magnuson Health Sciences C-wing	526-B	Pathology	1759	Active	Passed	53	122	25	52
1/18/2018	Magnuson Health Sciences C-wing	526-B	Pathology	1758	Active	Passed	66	132	25	52
7/21/2017	Magnuson Health Sciences D-wing	518	Pathology	1761	Active	Failed	63	153	19	52
7/21/2017	Magnuson Health Sciences D-wing	529	Pathology	937	Active	Passed	66	111	28	48
7/21/2017	Magnuson Health Sciences D-wing	785A	Restorative Dentistry	598	Active	Passed	75	145	30	36
7/21/2017	Magnuson Health Sciences D-wing	782	Restorative Dentistry	611	Active	Passed	63	97	23	36
7/21/2017	Magnuson Health Sciences D-wing	759	Restorative Dentistry	1157	Active	Passed	67	116	30	36
7/21/2017	Magnuson Health Sciences D-wing	560	Periodontics	946	Active	Passed	69	110	20	34

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/21/2017	Magnuson Health Sciences D-wing	559	Periodontics	945	Active	Passed	65	132	30	36
7/21/2017	Magnuson Health Sciences D-wing	532	Pathology	934	Active	Passed	58	121	29	48
7/21/2017	Magnuson Health Sciences D-wing	165B	Restorative Dentistry	1571	Active	Failed	63	218	18	38
7/21/2017	Magnuson Health Sciences D-wing	518	Pathology	1760	Active	Passed	65	118	25	52
7/21/2017	Magnuson Health Sciences D-wing	218A	Medical Genetics	594	Active	Passed	58	113	18	60
7/21/2017	Magnuson Health Sciences D-wing	514	Pathology	1768	Active	Passed	67	116	29	52
7/21/2017	Magnuson Health Sciences D-wing	430	Pharmacology	1798	Active	Passed	61	124	28	50
7/21/2017	Magnuson Health Sciences D-wing	430	Pharmacology	1801	Active	Passed	63	100	18	50
7/21/2017	Magnuson Health Sciences D-wing	426	Pharmacology	938	Active	Passed	58	86	28	48
7/21/2017	Magnuson Health Sciences D-wing	424	Pharmacology	1153	Active	Passed	70	98	29	48
7/21/2017	Magnuson Health Sciences D-wing	408	Pharmacology	1799	Active	Passed	55	103	24	50
7/21/2017	Magnuson Health Sciences D-wing	408	Pharmacology	1800	Active	Passed	53	93	18	50
7/21/2017	Magnuson Health Sciences D-wing	352	Dental Public Health Sciences	597	Inactive	Passed	0	0	0	35
7/21/2017	Magnuson Health Sciences D-wing	224	Oral Health Research	608	Active	Passed	62	102	18	38
7/21/2017	Magnuson Health Sciences D-wing	220	Periodontics	595	Active	Passed	57	124	21	56
7/21/2017	Magnuson Health Sciences D-wing	165A	Restorative Dentistry	1570	Active	Passed	68	102	27	98
7/21/2017	Magnuson Health Sciences D-wing	528	Pathology	936	Active	Passed	59	140	18	48
7/21/2017	Magnuson Health Sciences D-wing	252	Restorative Dentistry	596	Inactive	Passed	60	114	21	35
9/22/2017	Magnuson Health Sciences E-wing	174	Environmental Health	591	Active	Passed	64	112	20	48
9/22/2017	Magnuson Health Sciences E-wing	079A	Pathology	578	Active	Passed	68	122	23	48
9/22/2017	Magnuson Health Sciences E-wing	164B	Environmental Health	585	Active	Passed	61	101	21	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/22/2017	Magnuson Health Sciences E-wing	168	Environmental Health	586	Inactive	Failed	56	29	18	48
9/22/2017	Magnuson Health Sciences E-wing	426	Pharmacology	1572	Active	Passed	65	122	21	62
9/22/2017	Magnuson Health Sciences E-wing	410	Pharmacology	582	Active	Passed	66	78	18	48
9/22/2017	Magnuson Health Sciences E-wing	406	Pharmacology	939	Active	Passed	64	101	25	60
9/22/2017	Magnuson Health Sciences E-wing	504	Pathology	1757	Active	Passed	65	114	23	52
9/22/2017	Magnuson Health Sciences E-wing	506	Pathology	1755	Active	Failed	75	159	18	52
9/22/2017	Magnuson Health Sciences E-wing	506	Pathology	1754	Active	Passed	66	110	24	52
1/4/2018	Magnuson Health Sciences E-wing	164	Environmental Health	584	Active	Passed	61	96	18	48
1/18/2018	Magnuson Health Sciences E-wing	504	Pathology	1756	Active	Passed	65	104	25	52
6/6/2017	Magnuson Health Sciences F-wing	066	Pathobiology	176	Active	Passed	63	96	18	60
6/6/2017	Magnuson Health Sciences F-wing	428	Pharmacology	186	Active	Passed	58	109	28	58
6/6/2017	Magnuson Health Sciences F-wing	428	Pharmacology	192	Active	Passed	60	107	25	60
6/6/2017	Magnuson Health Sciences F-wing	410	Pharmacology	187	Active	Passed	59	93	20	50
6/6/2017	Magnuson Health Sciences F-wing	218A	Environmental Health	178	Active	Passed	59	114	18	38
6/6/2017	Magnuson Health Sciences F-wing	218	Environmental Health	180	Active	Passed	58	108	28	50
6/6/2017	Magnuson Health Sciences F-wing	218	Environmental Health	1770	Active	Passed	60	116	21	40
6/6/2017	Magnuson Health Sciences F-wing	442	Environmental Health	292	Active	Passed	62	106	18	80
6/6/2017	Magnuson Health Sciences F-wing	212	Physiology and Biophysics	980	Active	Passed	60	105	18	50
6/6/2017	Magnuson Health Sciences F-wing	166	Pathobiology	177	Active	Passed	62	102	20	60
6/6/2017	Magnuson Health Sciences F-wing	047	Environmental Health	2203	Active	Passed	60	118	18	58
6/6/2017	Magnuson Health Sciences F-wing	042	Pathobiology	921	Active	Passed	62	110	20	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
6/6/2017	Magnuson Health Sciences F-wing	218	Environmental Health	179	Active	Passed	61	109	28	50
6/6/2017	Magnuson Health Sciences F-wing	524	Biological Structure	2153	Active	Passed	62	94	18	60
6/6/2017	Magnuson Health Sciences F-wing	563	Environmental Health	316	Active	Passed	58	98	18	60
6/6/2017	Magnuson Health Sciences F-wing	504	Biological Structure	303	Active	Passed	58	108	28	38
6/6/2017	Magnuson Health Sciences F-wing	502	Biological Structure	947	Active	Passed	60	100	22	38
6/6/2017	Magnuson Health Sciences F-wing	518	Biological Structure	2152	Active	Passed	60	86	18	60
6/6/2017	Magnuson Health Sciences F-wing	530	Biological Structure	2154	Active	Failed	60	151	18	60
6/6/2017	Magnuson Health Sciences F-wing	542	Environmental Health	310	Active	Passed	62	105	27	48
6/6/2017	Magnuson Health Sciences F-wing	542	Environmental Health	309	Active	Passed	63	93	28	48
6/6/2017	Magnuson Health Sciences F-wing	553	Environmental Health	313	Active	Passed	60	124	18	60
6/6/2017	Magnuson Health Sciences F-wing	562	Environmental Health	314	Active	Passed	60	99	21	84
6/6/2017	Magnuson Health Sciences F-wing	553E	Environmental Health	312	Active	Passed	64	107	24	60
6/6/2017	Magnuson Health Sciences F-wing	047	Pathobiology	1557	Active	Passed	62	97	28	50
6/6/2017	Magnuson Health Sciences F-wing	511	Biological Structure	305	Active	Passed	62	115	24	60
8/24/2017	Magnuson Health Sciences F-wing	404	Pharmacology	188	Active	Failed	66	106	20	60
2/7/2018	Magnuson Health Sciences F-wing	457A	Environmental Health	298	Active	Passed	60	104	18	60
2/7/2018	Magnuson Health Sciences F-wing	443	Environmental Health	193	Active	Passed	63	107	18	60
2/7/2018	Magnuson Health Sciences F-wing	455	Environmental Health	297	Active	Passed	65	104	25	60
2/7/2018	Magnuson Health Sciences F-wing	456	Environmental Health	299	Active	Passed	64	127	21	60
2/7/2018	Magnuson Health Sciences F-wing	451A	Environmental Health	294	Active	Passed	65	107	27	60
2/7/2018	Magnuson Health Sciences F-wing	458	Environmental Health	300	Active	Passed	63	119	25	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/7/2018	Magnuson Health Sciences F-wing	466	Environmental Health	301	Active	Passed	65	86	21	60
2/7/2018	Magnuson Health Sciences F-wing	466	Environmental Health	302	Active	Passed	65	106	29	48
2/7/2018	Magnuson Health Sciences F-wing	454	Environmental Health	295	Active	Passed	63	98	18	60
2/7/2018	Magnuson Health Sciences F-wing	454	Environmental Health	296	Active	Passed	64	125	27	48
1/18/2018	Magnuson Health Sciences G-wing	402	Physiology and Biophysics	981	Active	Passed	63	123	28	38
1/18/2018	Magnuson Health Sciences G-wing	406	Physiology and Biophysics	982	Active	Passed	63	112	24	38
1/18/2018	Magnuson Health Sciences G-wing	524	Biological Structure	2155	Active	Passed	60	110	18	60
1/18/2018	Magnuson Health Sciences G-wing	412	Physiology and Biophysics	984	Active	Passed	63	133	24	38
1/18/2018	Magnuson Health Sciences G-wing	530	Biological Structure	2156	Active	Passed	62	120	18	60
1/18/2018	Magnuson Health Sciences G-wing	310	Microbiology	1831	Active	Passed	64	101	18	48
1/18/2018	Magnuson Health Sciences G-wing	230	Physiology and Biophysics	977	Active	Passed	62	106	24	62
1/18/2018	Magnuson Health Sciences G-wing	219A	Physiology and Biophysics	572	Active	Passed	63	92	24	50
1/18/2018	Magnuson Health Sciences G-wing	418	Physiology and Biophysics	983	Active	Passed	60	125	18	38
1/18/2018	Magnuson Health Sciences G-wing	320	Microbiology	978	Active	Failed	0	0	18	62
2/14/2018	Magnuson Health Sciences H-wing	058	Medicinal Chemistry	1179	Active	Passed	59	109	15	63
2/14/2018	Magnuson Health Sciences H-wing	064	Medicinal Chemistry	1176	Active	Failed	0	0	0	63
2/14/2018	Magnuson Health Sciences H-wing	064	Medicinal Chemistry	1177	Active	Passed	61	113	18	63
2/14/2018	Magnuson Health Sciences H-wing	058	Medicinal Chemistry	1178	Active	Passed	60	104	18	63
2/16/2018	Magnuson Health Sciences H-wing	059	Medicinal Chemistry	1188	Active	Passed	63	111	18	63
2/16/2018	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1171	Active	Passed	61	95	18	63
2/16/2018	Magnuson Health Sciences H-wing	067	Medicinal Chemistry	1191	Active	Passed	61	113	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/16/2018	Magnuson Health Sciences H-wing	053	Medicinal Chemistry	1182	Active	Passed	63	118	18	63
2/16/2018	Magnuson Health Sciences H-wing	067	Medicinal Chemistry	1190	Active	Passed	64	149	18	63
2/16/2018	Magnuson Health Sciences H-wing	073	Medicinal Chemistry	1169	Active	Failed	65	182	18	63
2/16/2018	Magnuson Health Sciences H-wing	073	Medicinal Chemistry	1170	Active	Passed	65	109	18	63
2/16/2018	Magnuson Health Sciences H-wing	059	Medicinal Chemistry	1189	Active	Passed	62	114	18	63
2/16/2018	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1172	Active	Passed	63	115	18	63
2/16/2018	Magnuson Health Sciences H-wing	072A	Medicinal Chemistry	1197	Active	Passed	64	129	18	63
2/16/2018	Magnuson Health Sciences H-wing	072A	Medicinal Chemistry	1196	Active	Passed	63	118	18	63
2/16/2018	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1174	Active	Passed	63	107	18	63
2/16/2018	Magnuson Health Sciences H-wing	078	Medicinal Chemistry	1173	Active	Passed	64	147	18	63
2/16/2018	Magnuson Health Sciences H-wing	064	Medicinal Chemistry	1175	Active	Passed	61	82	18	63
2/20/2018	Magnuson Health Sciences H-wing	126	Immunology	1840	Active	Passed	60	94	18	52
2/20/2018	Magnuson Health Sciences H-wing	279A	Pharmacy	1220	Active	Passed	62	98	18	63
2/20/2018	Magnuson Health Sciences H-wing	159	Medicinal Chemistry	1203	Active	Passed	62	92	18	63
2/20/2018	Magnuson Health Sciences H-wing	179A	Medicinal Chemistry	1207	Active	Passed	63	116	18	63
2/20/2018	Magnuson Health Sciences H-wing	179A	Medicinal Chemistry	1206	Active	Failed	64	184	18	63
2/20/2018	Magnuson Health Sciences H-wing	168	Medicinal Chemistry	1209	Active	Passed	62	87	18	63
2/20/2018	Magnuson Health Sciences H-wing	132	Genetics	1839	Inactive	Passed	0	0	0	52
2/20/2018	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1199	Active	Passed	58	81	18	63
2/20/2018	Magnuson Health Sciences H-wing	053	Medicinal Chemistry	1183	Inactive	Passed	0	0	0	63
2/20/2018	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1201	Active	Passed	60	102	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/20/2018	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1200	Active	Passed	60	110	18	63
2/20/2018	Magnuson Health Sciences H-wing	068	Medicinal Chemistry	1198	Active	Passed	59	122	18	63
2/20/2018	Magnuson Health Sciences H-wing	168	Medicinal Chemistry	1208	Active	Passed	60	78	18	63
2/20/2018	Magnuson Health Sciences H-wing	204	Physiology and Biophysics	2146	Active	Passed	58	103	18	72
2/20/2018	Magnuson Health Sciences H-wing	253	Pharmacy	1216	Active	Failed	67	239	18	51
2/20/2018	Magnuson Health Sciences H-wing	253	Pharmacy	1217	Active	Passed	65	133	18	51
2/20/2018	Magnuson Health Sciences H-wing	265	Pharmacy	1219	Active	Passed	61	94	18	63
2/20/2018	Magnuson Health Sciences H-wing	259	Pharmacy	1218	Active	Passed	63	107	18	63
2/20/2018	Magnuson Health Sciences H-wing	268	Pharmacy	1221	Active	Failed	61	100	18	63
2/20/2018	Magnuson Health Sciences H-wing	264	Pharmacy	1212	Active	Passed	59	100	18	51
2/21/2018	Magnuson Health Sciences H-wing	330	Bioengineering	1914	Active	Passed	59	84	18	40
2/21/2018	Magnuson Health Sciences H-wing	428	Physiology and Biophysics	2151	Active	Passed	62	96	18	60
2/21/2018	Magnuson Health Sciences H-wing	426	Physiology and Biophysics	2150	Active	Passed	58	107	18	60
2/21/2018	Magnuson Health Sciences H-wing	418	Physiology and Biophysics	1098	Active	Passed	62	135	18	50
2/21/2018	Magnuson Health Sciences H-wing	404	Physiology and Biophysics	2149	Active	Passed	59	97	18	72
2/21/2018	Magnuson Health Sciences H-wing	353	Pharmacy	1223	Active	Passed	65	122	18	63
2/21/2018	Magnuson Health Sciences H-wing	459	Immunology	1226	Active	Passed	63	106	18	63
2/21/2018	Magnuson Health Sciences H-wing	353	Pharmacy	1222	Active	Failed	65	216	18	63
2/21/2018	Magnuson Health Sciences H-wing	320	Physiology and Biophysics	2148	Active	Passed	57	97	18	72
2/21/2018	Magnuson Health Sciences H-wing	330	Microbiology	1099	Active	Passed	58	103	18	36
2/21/2018	Magnuson Health Sciences H-wing	153	Medicinal Chemistry	1202	Active	Passed	64	97	18	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/21/2018	Magnuson Health Sciences H-wing	514	Biological Structure	2159	Active	Passed	60	107	18	60
2/21/2018	Magnuson Health Sciences H-wing	561	Immunology	1231	Active	Failed	62	111	18	63
2/21/2018	Magnuson Health Sciences H-wing	578	Immunology	1229	Active	Passed	65	150	18	63
2/21/2018	Magnuson Health Sciences H-wing	579	Immunology	1228	Active	Passed	65	88	18	63
2/21/2018	Magnuson Health Sciences H-wing	506	Biological Structure	2158	Active	Passed	61	104	18	72
2/21/2018	Magnuson Health Sciences H-wing	502	Biological Structure	2157	Active	Passed	61	98	18	72
2/21/2018	Magnuson Health Sciences H-wing	478	Immunology	1225	Active	Failed	66	165	18	63
2/21/2018	Magnuson Health Sciences H-wing	479	Immunology	1224	Active	Failed	65	154	18	63
2/21/2018	Magnuson Health Sciences H-wing	260	Pharmacy	1214	Active	Failed	65	200	18	51
2/21/2018	Magnuson Health Sciences H-wing	481B	Immunology	1227	Active	Failed	71	151	18	63
2/21/2018	Magnuson Health Sciences H-wing	260	Pharmacy	1213	Active	Passed	65	99	18	51
2/21/2018	Magnuson Health Sciences H-wing	310J	Physiology and Biophysics	2147	Active	Passed	54	88	18	72
2/21/2018	Magnuson Health Sciences H-wing	551	Immunology	1230	Active	Passed	67	182	18	63
1/5/2018	Magnuson Health Sciences I-wing	089D	Regional Primate Research Center	1550	Active	Passed	60	114	20	50
1/5/2018	Magnuson Health Sciences I-wing	097	Medicinal Chemistry	1254	Inactive	Passed	0	0	0	51
1/5/2018	Magnuson Health Sciences I-wing	093A	Medicinal Chemistry	1255	Active	Passed	63	95	18	39
1/5/2018	Magnuson Health Sciences I-wing	093-E	Medicinal Chemistry	1256	Active	Passed	64	122	18	63
1/5/2018	Magnuson Health Sciences I-wing	204A	Medicine	899	Active	Passed	62	104	28	60
1/5/2018	Magnuson Health Sciences I-wing	204F	Medicine	1041	Active	Passed	62	135	24	60
1/8/2018	Magnuson Health Sciences I-wing	332	Urology	545	Active	Passed	62	107	22	48
1/8/2018	Magnuson Health Sciences I-wing	604E	Howard Hughes Medical Institute	973	Active	Passed	65	112	24	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/8/2018	Magnuson Health Sciences I-wing	534-D	Biological Structure	556	Inactive	Passed	0	0	0	60
1/8/2018	Magnuson Health Sciences I-wing	534-F	Biological Structure	555	Active	Passed	64	103	18	36
1/8/2018	Magnuson Health Sciences I-wing	534-G	Biological Structure	554	Active	Passed	63	89	18	60
1/8/2018	Magnuson Health Sciences I-wing	104A	Allergy and Infectious Diseases	897	Active	Passed	62	131	18	60
1/8/2018	Magnuson Health Sciences I-wing	555	Regional Primate Research Center	557	Active	Passed	63	105	18	36
1/8/2018	Magnuson Health Sciences I-wing	604D	Howard Hughes Medical Institute	971	Active	Passed	64	107	18	60
1/8/2018	Magnuson Health Sciences I-wing	516C	Biological Structure	2160	Active	Passed	63	90	18	72
1/8/2018	Magnuson Health Sciences I-wing	604K	Comparative Medicine	968	Active	Passed	64	106	24	60
1/8/2018	Magnuson Health Sciences I-wing	604J	Howard Hughes Medical Institute	966	Active	Passed	63	123	24	60
1/8/2018	Magnuson Health Sciences I-wing	607J	Howard Hughes Medical Institute	970	Active	Passed	66	112	24	60
1/8/2018	Magnuson Health Sciences I-wing	607K	Howard Hughes Medical Institute	967	Active	Passed	66	114	24	60
1/8/2018	Magnuson Health Sciences I-wing	607E	Howard Hughes Medical Institute	969	Active	Passed	65	110	24	60
1/8/2018	Magnuson Health Sciences I-wing	329	Regional Primate Research Center	546	Active	Passed	65	116	24	60
1/8/2018	Magnuson Health Sciences I-wing	I-312	Regional Primate Research Center	2107	Active	Passed	62	103	18	52
1/9/2018	Magnuson Health Sciences I-wing	164A	Medicine	965	Active	Passed	65	98	18	60
1/9/2018	Magnuson Health Sciences I-wing	164G	Medicine	964	Active	Passed	64	119	24	60
1/9/2018	Magnuson Health Sciences I-wing	744	Regional Primate Research Center	1549	Active	Passed	63	111	24	60
1/18/2018	Magnuson Health Sciences I-wing	004	Regional Primate Research Center	898	Active	Passed	64	119	24	60
5/26/2017	Magnuson Health Sciences J-wing	506	Biochemistry	2228	Active	Passed	58	106	18	86
5/26/2017	Magnuson Health Sciences J-wing	136	Microbiology	2240	Active	Passed	55	86	18	50
5/26/2017	Magnuson Health Sciences J-wing	512	Biochemistry	248	Active	Passed	55	102	19	60

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/26/2017	Magnuson Health Sciences J-wing	236	Microbiology	2250	Active	Passed	55	109	18	50
5/26/2017	Magnuson Health Sciences J-wing	661A	Howard Hughes Medical Institute	866	Active	Passed	61	102	24	60
5/26/2017	Magnuson Health Sciences J-wing	236	Microbiology	2247	Active	Passed	54	79	18	50
5/26/2017	Magnuson Health Sciences J-wing	236	Microbiology	2249	Active	Passed	56	88	18	50
5/26/2017	Magnuson Health Sciences J-wing	212	Microbiology	2246	Active	Passed	52	89	18	50
5/26/2017	Magnuson Health Sciences J-wing	212	Microbiology	2245	Active	Passed	50	63	18	450
5/26/2017	Magnuson Health Sciences J-wing	212	Microbiology	2243	Active	Passed	53	80	18	50
5/26/2017	Magnuson Health Sciences J-wing	136	Microbiology	2239	Active	Passed	56	91	18	50
5/26/2017	Magnuson Health Sciences J-wing	312	Biochemistry	2013	Active	Passed	54	100	18	50
5/26/2017	Magnuson Health Sciences J-wing	136	Microbiology	2241	Active	Passed	54	84	18	50
5/26/2017	Magnuson Health Sciences J-wing	312	Biochemistry	2019	Active	Passed	56	96	18	50
5/26/2017	Magnuson Health Sciences J-wing	112	Microbiology	2237	Active	Passed	56	68	18	50
5/26/2017	Magnuson Health Sciences J-wing	112	Microbiology	2236	Active	Passed	53	73	18	50
5/26/2017	Magnuson Health Sciences J-wing	112	Microbiology	2235	Active	Passed	54	73	18	50
5/26/2017	Magnuson Health Sciences J-wing	112	Microbiology	2238	Active	Passed	53	69	18	50
5/26/2017	Magnuson Health Sciences J-wing	061	Biochemistry	1152	Active	Passed	60	106	18	50
5/26/2017	Magnuson Health Sciences J-wing	061	Biochemistry	1151	Active	Failed	64	161	18	50
5/26/2017	Magnuson Health Sciences J-wing	661D	Howard Hughes Medical Institute	867	Active	Passed	62	109	20	60
5/26/2017	Magnuson Health Sciences J-wing	681A	Howard Hughes Medical Institute	952	Active	Passed	64	97	23	6
5/26/2017	Magnuson Health Sciences J-wing	681D	Howard Hughes Medical Institute	948	Active	Passed	62	89	20	60
5/26/2017	Magnuson Health Sciences J-wing	136	Microbiology	2242	Active	Passed	54	92	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/26/2017	Magnuson Health Sciences J-wing	434	Biochemistry	2008	Active	Passed	58	99	18	50
5/26/2017	Magnuson Health Sciences J-wing	562	Biochemistry	256	Active	Passed	59	104	24	60
5/26/2017	Magnuson Health Sciences J-wing	555	Biochemistry	255	Active	Passed	56	112	28	52
5/26/2017	Magnuson Health Sciences J-wing	534	Biochemistry	2006	Active	Passed	60	92	18	50
5/26/2017	Magnuson Health Sciences J-wing	534	Biochemistry	2005	Active	Passed	60	105	18	50
5/26/2017	Magnuson Health Sciences J-wing	534	Biochemistry	2003	Active	Passed	57	118	18	50
5/26/2017	Magnuson Health Sciences J-wing	534	Biochemistry	2004	Active	Passed	57	101	18	50
5/26/2017	Magnuson Health Sciences J-wing	512	Bioengineering	1821	Inactive	Passed	0	0	18	48
5/26/2017	Magnuson Health Sciences J-wing	236	Microbiology	2248	Active	Passed	56	72	18	50
5/26/2017	Magnuson Health Sciences J-wing	611D	Howard Hughes Medical Institute	873	Active	Passed	60	119	18	60
5/26/2017	Magnuson Health Sciences J-wing	611A	Howard Hughes Medical Institute	872	Active	Passed	58	89	18	60
5/26/2017	Magnuson Health Sciences J-wing	434	Biochemistry	2007	Active	Passed	56	103	18	50
5/26/2017	Magnuson Health Sciences J-wing	462	Biochemistry	2011	Active	Passed	55	104	18	50
5/26/2017	Magnuson Health Sciences J-wing	434	Biochemistry	2009	Active	Passed	55	105	18	50
5/26/2017	Magnuson Health Sciences J-wing	434	Biochemistry	2010	Active	Passed	57	92	18	50
5/26/2017	Magnuson Health Sciences J-wing	334	Biochemistry	2014	Active	Passed	56	100	18	50
5/26/2017	Magnuson Health Sciences J-wing	334	Biochemistry	2015	Active	Passed	57	120	18	50
5/26/2017	Magnuson Health Sciences J-wing	631A	Howard Hughes Medical Institute	871	Active	Passed	63	103	28	60
5/26/2017	Magnuson Health Sciences J-wing	334	Biochemistry	2012	Active	Passed	55	114	18	50
5/26/2017	Magnuson Health Sciences J-wing	334	Biochemistry	2016	Active	Passed	57	107	18	50
5/26/2017	Magnuson Health Sciences J-wing	312	Biochemistry	2017	Active	Passed	56	108	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/26/2017	Magnuson Health Sciences J-wing	312	Biochemistry	2018	Active	Passed	57	98	18	50
5/26/2017	Magnuson Health Sciences J-wing	631D	Howard Hughes Medical Institute	870	Active	Passed	61	115	18	60
8/21/2017	Magnuson Health Sciences J-wing	212	Microbiology	2244	Active	Passed	58	66	18	50
1/4/2018	Magnuson Health Sciences J-wing	681H	Pharmacy	949	Active	Passed	69	116	24	60
8/30/2017	Magnuson Health Sciences K-wing	563	Physiology and Biophysics	1491	Active	Passed	62	122	18	63
8/30/2017	Magnuson Health Sciences K-wing	565	Physiology and Biophysics	1490	Inactive	Passed	0	0	0	51
8/30/2017	Magnuson Health Sciences K-wing	526	Pharmacology	1485	Active	Passed	64	107	18	63
8/30/2017	Magnuson Health Sciences K-wing	533	Pathology	1481	Active	Passed	62	115	18	63
8/30/2017	Magnuson Health Sciences K-wing	562	Pharmacology	1489	Active	Passed	64	127	18	51
8/30/2017	Magnuson Health Sciences K-wing	561	Physiology and Biophysics	1493	Active	Failed	64	230	18	51
8/30/2017	Magnuson Health Sciences K-wing	555	Physiology and Biophysics	1492	Active	Passed	62	133	18	63
8/30/2017	Magnuson Health Sciences K-wing	560	Pharmacology	1488	Active	Passed	62	106	18	63
8/30/2017	Magnuson Health Sciences K-wing	522	Pharmacology	1484	Active	Passed	62	109	18	63
8/30/2017	Magnuson Health Sciences K-wing	516	Pharmacology	1483	Active	Passed	63	113	18	63
8/30/2017	Magnuson Health Sciences K-wing	554	Pharmacology	1487	Active	Passed	63	115	18	63
8/30/2017	Magnuson Health Sciences K-wing	527	Pathology	1482	Active	Passed	61	105	18	63
8/30/2017	Magnuson Health Sciences K-wing	544	Pharmacology	1486	Active	Failed	63	87	18	51
8/31/2017	Magnuson Health Sciences K-wing	024B	Comparative Medicine	1458	Inactive	Passed	0	0	0	38
8/31/2017	Magnuson Health Sciences K-wing	030	Comparative Medicine	1459	Active	Passed	62	97	24	38
8/31/2017	Magnuson Health Sciences K-wing	017-b	Comparative Medicine	2260	Active	Passed	61	89	18	63
8/31/2017	Magnuson Health Sciences K-wing	007F	Comparative Medicine	1456	Active	Passed	65	88	24	38

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/6/2017	Magnuson Health Sciences K-wing	085	Pathology	1465	Active	Passed	62	138	18	63
9/6/2017	Magnuson Health Sciences K-wing	065	Pathology	1467	Active	Passed	60	113	18	63
9/6/2017	Magnuson Health Sciences K-wing	058	Pathology	1462	Active	Passed	62	110	18	63
9/6/2017	Magnuson Health Sciences K-wing	460	Biological Structure	1502	Active	Passed	62	102	18	63
9/6/2017	Magnuson Health Sciences K-wing	326	Genome Sciences	1506	Active	Passed	63	125	18	63
9/6/2017	Magnuson Health Sciences K-wing	316	Molecular Biotechnology	1508	Active	Passed	65	108	18	63
9/6/2017	Magnuson Health Sciences K-wing	327	Genome Sciences	1510	Active	Passed	60	102	18	63
9/6/2017	Magnuson Health Sciences K-wing	327	Genome Sciences	1509	Active	Passed	62	101	18	38
9/6/2017	Magnuson Health Sciences K-wing	463	Microbiology	1500	Active	Passed	64	135	18	63
9/6/2017	Magnuson Health Sciences K-wing	455	Microbiology	1499	Active	Passed	63	118	18	63
9/6/2017	Magnuson Health Sciences K-wing	464	Biological Structure	1501	Active	Passed	61	112	18	63
9/6/2017	Magnuson Health Sciences K-wing	084	Pathology	1463	Active	Passed	61	114	18	63
9/6/2017	Magnuson Health Sciences K-wing	460	Biological Structure	1505	Active	Passed	62	116	18	63
9/6/2017	Magnuson Health Sciences K-wing	088	Pathology	1464	Active	Passed	63	148	18	63
9/6/2017	Magnuson Health Sciences K-wing	460	Biological Structure	1503	Active	Passed	63	115	18	63
9/6/2017	Magnuson Health Sciences K-wing	426	Biochemistry	1494	Active	Passed	61	112	18	63
9/6/2017	Magnuson Health Sciences K-wing	416	Biological Structure	1496	Active	Failed	63	109	18	63
9/6/2017	Magnuson Health Sciences K-wing	427	Microbiology	1497	Active	Passed	64	121	18	63
9/6/2017	Magnuson Health Sciences K-wing	433	Surgery	1498	Active	Passed	63	106	18	63
9/6/2017	Magnuson Health Sciences K-wing	081	Pathology	1466	Active	Passed	63	113	18	63
9/6/2017	Magnuson Health Sciences K-wing	307	Microbiology	2145	Active	Failed	64	153	18	72

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/6/2017	Magnuson Health Sciences K-wing	460	Biological Structure	1504	Active	Passed	63	124	18	63
9/6/2017	Magnuson Health Sciences K-wing	322	Molecular Biotechnology	1507	Active	Passed	63	125	18	63
9/7/2017	Magnuson Health Sciences K-wing	363	Genome Sciences	1514	Active	Passed	61	139	18	63
9/7/2017	Magnuson Health Sciences K-wing	360	Genome Sciences	1515	Active	Passed	60	123	18	63
9/7/2017	Magnuson Health Sciences K-wing	354	Pharmacology	1516	Active	Passed	62	129	18	63
9/7/2017	Magnuson Health Sciences K-wing	359	Genome Sciences	1513	Active	Passed	59	140	18	63
9/11/2017	Magnuson Health Sciences K-wing	265	Medicine	1526	Active	Passed	65	127	18	51
9/11/2017	Magnuson Health Sciences K-wing	233	Neurology	1517	Active	Passed	60	107	18	63
9/11/2017	Magnuson Health Sciences K-wing	227	Neurology	1518	Active	Passed	60	80	24	63
9/11/2017	Magnuson Health Sciences K-wing	216	Genetics	1519	Active	Passed	62	108	18	63
9/11/2017	Magnuson Health Sciences K-wing	222	Genetics	1520	Active	Passed	64	123	18	63
9/11/2017	Magnuson Health Sciences K-wing	226	Genetics	1521	Active	Passed	63	115	18	63
9/11/2017	Magnuson Health Sciences K-wing	254	Medicine	1523	Active	Passed	61	123	18	63
9/11/2017	Magnuson Health Sciences K-wing	260	Medicine	1525	Active	Passed	64	127	18	63
9/11/2017	Magnuson Health Sciences K-wing	263	Genetics	1527	Active	Passed	63	143	18	63
9/11/2017	Magnuson Health Sciences K-wing	262	Genetics	1524	Active	Passed	65	117	18	51
9/11/2017	Magnuson Health Sciences K-wing	244	Medicine	1522	Active	Passed	64	128	18	51
9/11/2017	Magnuson Health Sciences K-wing	257	Genetics	1528	Active	Passed	62	136	18	63
9/12/2017	Magnuson Health Sciences K-wing	127	Cardiology, Medicine	1468	Active	Passed	63	99	18	63
9/12/2017	Magnuson Health Sciences K-wing	126	Medicine	1478	Active	Passed	62	100	18	63
9/12/2017	Magnuson Health Sciences K-wing	122	Medicine	1479	Active	Passed	65	131	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/12/2017	Magnuson Health Sciences K-wing	154	Genetics	1476	Active	Passed	63	115	18	63
9/12/2017	Magnuson Health Sciences K-wing	160	Genetics	1475	Active	Passed	63	131	18	63
9/12/2017	Magnuson Health Sciences K-wing	161	Medicine	1470	Active	Passed	62	121	18	63
9/12/2017	Magnuson Health Sciences K-wing	155	Medicine	1469	Active	Passed	63	132	18	63
9/12/2017	Magnuson Health Sciences K-wing	165	Medicine	1471	Active	Failed	65	151	18	63
9/12/2017	Magnuson Health Sciences K-wing	167	Genetics	1473	Active	Passed	64	139	18	51
9/12/2017	Magnuson Health Sciences K-wing	107	Pathology	1804	Active	Passed	65	128	18	64
9/12/2017	Magnuson Health Sciences K-wing	038	Pathology	1460	Inactive	Passed	0	0	0	51
9/12/2017	Magnuson Health Sciences K-wing	116	Microbiology	1480	Active	Passed	64	124	18	63
12/29/2017	Magnuson Health Sciences K-wing	162	Genetics	1474	Active	Passed	64	119	18	51
7/28/2017	Magnuson Health Sciences RR-wing	348	Pediatrics	493	Active	Passed	67	148	18	35
8/16/2017	Magnuson Health Sciences RR-wing	637	Neurology	507	Active	Passed	65	134	22	60
8/16/2017	Magnuson Health Sciences RR-wing	739	Neurological Surgery	510	Active	Passed	65	119	18	50
8/16/2017	Magnuson Health Sciences RR-wing	606	Obstetrics and Gynecology	505	Active	Passed	66	111	18	62
8/16/2017	Magnuson Health Sciences RR-wing	612	Obstetrics and Gynecology	514	Inactive	Passed	0	0	0	60
8/16/2017	Magnuson Health Sciences RR-wing	711	Neurology	1155	Active	Passed	66	119	17	50
8/16/2017	Magnuson Health Sciences RR-wing	815	Ophthalmology	516	Active	Passed	72	96	24	60
8/16/2017	Magnuson Health Sciences RR-wing	813	Ophthalmology	518	Active	Passed	71	114	24	60
8/16/2017	Magnuson Health Sciences RR-wing	837	Ophthalmology	519	Active	Passed	72	105	18	59
8/16/2017	Magnuson Health Sciences RR-wing	751	Neurological Surgery	1563	Active	Passed	68	136	17	62
8/16/2017	Magnuson Health Sciences RR-wing	747	Neurological Surgery	512	Active	Passed	72	135	24	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/16/2017	Magnuson Health Sciences RR-wing	610	Obstetrics and Gynecology	506	Active	Passed	68	115	24	60
8/17/2017	Magnuson Health Sciences RR-wing	540	Obstetrics and Gynecology	959	Active	Passed	75	118	28	50
8/17/2017	Magnuson Health Sciences RR-wing	337	Pediatrics	489	Active	Passed	65	128	21	59
8/17/2017	Magnuson Health Sciences RR-wing	306	Pediatrics	485	Active	Passed	65	91	20	59
8/17/2017	Magnuson Health Sciences RR-wing	309	Pediatrics	487	Active	Passed	65	109	18	59
8/17/2017	Magnuson Health Sciences RR-wing	345	Pediatrics	492	Active	Failed	64	151	20	59
8/17/2017	Magnuson Health Sciences RR-wing	335	Pediatrics	488	Active	Failed	63	95	18	59
8/17/2017	Magnuson Health Sciences RR-wing	344	Pediatrics	499	Active	Passed	64	96	21	59
8/17/2017	Magnuson Health Sciences RR-wing	410	Anesthesiology	215	Active	Passed	65	105	25	62
8/17/2017	Magnuson Health Sciences RR-wing	437	Pediatrics	495	Active	Passed	66	121	22	50
8/17/2017	Magnuson Health Sciences RR-wing	436	Anesthesiology	494	Active	Passed	69	109	29	62
8/17/2017	Magnuson Health Sciences RR-wing	438	Anesthesiology	496	Active	Passed	68	132	29	62
8/17/2017	Magnuson Health Sciences RR-wing	535	Pediatrics	1734	Active	Passed	74	149	28	59
8/17/2017	Magnuson Health Sciences RR-wing	505	Medicine	500	Active	Passed	66	114	18	64
8/21/2017	Magnuson Health Sciences RR-wing	106	Gastroenterology	474	Active	Passed	61	124	18	59
8/21/2017	Magnuson Health Sciences RR-wing	249	Pediatrics	483	Active	Passed	62	100	28	59
8/21/2017	Magnuson Health Sciences RR-wing	107	Gastroenterology	475	Active	Passed	62	94	18	59
8/21/2017	Magnuson Health Sciences RR-wing	108	Gastroenterology	476	Active	Passed	62	92	16	59
8/21/2017	Magnuson Health Sciences RR-wing	109	Gastroenterology	477	Active	Passed	64	111	20	60
8/21/2017	Magnuson Health Sciences RR-wing	012	Radiation Oncology	472	Active	Passed	68	107	30	54
8/21/2017	Magnuson Health Sciences RR-wing	249	Pediatrics	484	Active	Passed	63	106	28	59

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/21/2017	Magnuson Health Sciences RR-wing	247	Pediatrics	481	Active	Failed	63	172	22	59
8/29/2017	Magnuson Health Sciences RR-wing	016	Radiation Oncology	473	Active	Passed	71	98	21	59
8/29/2017	Magnuson Health Sciences RR-wing	338	Pediatrics	490	Active	Passed	67	139	24	59
8/23/2017	Magnuson Health Sciences T-wing	577	Physiology and Biophysics	953	Active	Passed	67	98	18	82
8/23/2017	Magnuson Health Sciences T-wing	276	Academic Support Services	1096	Active	Passed	66	114	25	35
8/23/2017	Magnuson Health Sciences T-wing	293 S	Genome Sciences	1859	Active	Passed	71	122	18	60
8/23/2017	Magnuson Health Sciences T-wing	293 S	Laboratory Medicine	1070	Active	Failed	71	142	18	48
8/23/2017	Magnuson Health Sciences T-wing	378	Academic Support Services	2021	Active	Passed	66	96	20	82
8/23/2017	Magnuson Health Sciences T-wing	564	Environmental Health	1165	Active	Passed	62	107	18	82
8/23/2017	Magnuson Health Sciences T-wing	588A	Academic Support Services	1548	Active	Passed	76	112	24	36
8/23/2017	Magnuson Health Sciences T-wing	592	Academic Support Services	961	Active	Passed	67	116	24	72
8/23/2017	Magnuson Health Sciences T-wing	592	Academic Support Services	960	Active	Passed	64	96	24	72
8/23/2017	Magnuson Health Sciences T-wing	594	Academic Support Services	956	Active	Passed	66	130	20	35
8/23/2017	Magnuson Health Sciences T-wing	638	School of Nursing	1564	Active	Passed	67	99	18	38
8/23/2017	Magnuson Health Sciences T-wing	640	School of Nursing	954	Active	Passed	65	138	26	35
8/23/2017	Magnuson Health Sciences T-wing	565	Laboratory Medicine	958	Active	Passed	64	105	18	82
8/24/2017	Magnuson Health Sciences T-wing	163 K	Regional Primate Research Center	1072	Active	Passed	64	90	24	48
8/24/2017	Magnuson Health Sciences T-wing	163 A	Genetics	1074	Active	Passed	64	110	24	50
8/24/2017	Magnuson Health Sciences T-wing	163 A	Genetics	1075	Active	Passed	65	91	20	48
8/24/2017	Magnuson Health Sciences T-wing	140L	Comparative Medicine	1616	Active	Passed	73	99	18	50
8/24/2017	Magnuson Health Sciences T-wing	163 N	Medicine	1071	Active	Passed	62	103	20	48

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/24/2017	Magnuson Health Sciences T-wing	163 K	Regional Primate Research Center	1073	Active	Passed	65	135	18	48
8/29/2017	Magnuson Health Sciences T-wing	274B	Radiation Safety	1095	Active	Passed	71	114	25	35
8/29/2017	Magnuson Health Sciences T-wing	152	Comparative Medicine	922	Active	Passed	65	99	20	60
8/29/2017	Magnuson Health Sciences T-wing	576	Biochemistry	955	Active	Passed	72	130	20	82
11/27/2017	MARINE SCIENCES	215	School of Oceanography	876	Active	Passed	61	100	18	36
11/27/2017	MARINE SCIENCES	365	School of Oceanography	705	Active	Failed	63	110	18	36
11/27/2017	MARINE SCIENCES	371	School of Oceanography	706	Active	Passed	62	140	18	36
11/27/2017	MARINE SCIENCES	253	School of Oceanography	775	Active	Failed	66	160	18	36
11/27/2017	MARINE SCIENCES	273	School of Oceanography	776	Active	Passed	62	128	18	36
11/27/2017	MARINE SCIENCES	223	School of Oceanography	905	Active	Passed	62	105	18	36
11/27/2017	MARINE SCIENCES	221	School of Oceanography	774	Active	Passed	63	106	18	36
11/27/2017	MARINE SCIENCES	209	School of Oceanography	672	Active	Failed	65	150	18	36
11/27/2017	MARINE SCIENCES	209	School of Oceanography	671	Active	Passed	64	121	18	60
11/27/2017	MARINE SCIENCES	207	School of Oceanography	670	Active	Failed	65	152	18	36
11/27/2017	MARINE SCIENCES	203	School of Oceanography	669	Active	Passed	66	138	18	48
11/27/2017	MARINE SCIENCES	319	School of Oceanography	701	Active	Passed	62	99	18	36
11/27/2017	MARINE SCIENCES	307	School of Oceanography	777	Active	Passed	64	106	18	36
11/27/2017	MARINE SCIENCES	355	School of Oceanography	702	Active	Passed	65	118	18	48
11/27/2017	MARINE SCIENCES	361	School of Oceanography	2201	Active	Passed	62	112	18	36
11/27/2017	MARINE SCIENCES	357	School of Oceanography	703	Active	Passed	61	130	18	36
12/6/2017	MARINE SCIENCES	217	School of Oceanography	773	Active	Passed	62	131	24	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/19/2017	MARINE STUDIES	170	Institute for Food Science and Technology	779	Inactive	Passed	0	0	0	50
12/19/2017	MARINE STUDIES	170	Institute for Food Science and Technology	780	Active	Passed	64	102	25	50
12/19/2017	MARINE STUDIES	176	Institute for Food Science and Technology	782	Active	Passed	65	130	22	50
12/19/2017	MARINE STUDIES	274	Institute for Food Science and Technology	783	Active	Passed	69	155	23	38
12/19/2017	MARINE STUDIES	276	Institute for Food Science and Technology	786	Active	Passed	65	116	31	38
12/19/2017	MARINE STUDIES	276	Institute for Food Science and Technology	785	Active	Passed	64	110	31	38
12/19/2017	MARINE STUDIES	277	Institute for Food Science and Technology	1815	Active	Passed	66	122	28	52
12/19/2017	MARINE STUDIES	176	Institute for Food Science and Technology	781	Active	Passed	64	96	18	50
12/19/2017	MARINE STUDIES	271	Institute for Food Science and Technology	787	Active	Passed	64	94	24	50
3/29/2017	MECHANICAL ENGINEERING	G 27	Mechanical Engineering	1729	Active	Passed	66	123	18	63
3/29/2017	MECHANICAL ENGINEERING	G 04	Mechanical Engineering	45	Active	Passed	71	101	27	38
8/15/2017	MECHANICAL ENGINEERING	G 041	Mechanical Engineering	2459	Active	Passed	61	111	18	62
8/15/2017	MECHANICAL ENGINEERING	B004	Mechanical Engineering	2544	Active	Failed	72	93	18	
8/29/2017	MERRILL HALL	51	Urban Horticulture Division	1885	Active	Passed	67	92	18	51
8/29/2017	MERRILL HALL	52	Urban Horticulture Division	1886	Active	Passed	68	93	18	51
8/29/2017	MERRILL HALL	50	Urban Horticulture Division	1884	Active	Passed	65	111	18	51
8/29/2017	MERRILL HALL	10	Urban Horticulture Division	1887	Active	Passed	67	107	18	51
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2269	Active	Passed	63	80	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2268	Active	Passed	63	89	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2264	Active	Passed	60	67	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2270	Active	Passed	62	78	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2267	Active	Passed	60	76	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2265	Active	Passed	62	91	18	63
12/27/2017	Molecular Engineering Building	440	Interdisciplinary	2261	Active	Passed	59	75	18	63
12/27/2017	Molecular Engineering Building	440	Interdisciplinary	2262	Active	Passed	60	86	18	63
12/27/2017	Molecular Engineering Building	G-021	Interdisciplinary	2312	Active	Passed	60	73	18	63
12/27/2017	Molecular Engineering Building	G-022	Interdisciplinary	2313	Active	Passed	60	78	18	63
12/27/2017	Molecular Engineering Building	G-042	Interdisciplinary	2311	Active	Passed	61	74	18	63
12/27/2017	Molecular Engineering Building	G-042	Interdisciplinary	2309	Active	Passed	61	84	18	63
12/27/2017	Molecular Engineering Building	G-042	Interdisciplinary	2310	Active	Passed	61	73	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2266	Active	Passed	62	80	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2287	Active	Passed	62	79	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2290	Active	Passed	62	87	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2289	Active	Passed	62	87	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2288	Active	Passed	63	93	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2293	Active	Passed	63	81	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2292	Active	Passed	62	82	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2277	Active	Passed	62	76	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2291	Active	Passed	63	81	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2286	Active	Passed	64	85	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2285	Active	Passed	63	72	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2281	Active	Passed	63	72	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2280	Active	Passed	62	78	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2271	Active	Passed	62	78	18	63
12/27/2017	Molecular Engineering Building	240	Interdisciplinary	2279	Active	Passed	64	98	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2276	Active	Passed	62	97	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2275	Active	Passed	63	81	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2274	Active	Passed	62	76	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2273	Active	Passed	62	83	18	63
12/27/2017	Molecular Engineering Building	340	Interdisciplinary	2272	Active	Passed	61	73	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2305	Active	Passed	62	80	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2304	Active	Passed	60	80	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2303	Active	Passed	61	71	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2302	Active	Passed	62	89	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2301	Active	Passed	63	73	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2307	Active	Passed	62	81	18	63
12/28/2017	Molecular Engineering Building	240	Interdisciplinary	2282	Active	Passed	62	83	18	63
12/28/2017	Molecular Engineering Building	140-B	Interdisciplinary	2295	Active	Passed	61	82	18	87
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2300	Active	Passed	62	93	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2308	Active	Passed	61	82	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/28/2017	Molecular Engineering Building	240	Interdisciplinary	2284	Active	Passed	62	73	18	63
12/28/2017	Molecular Engineering Building	240	Interdisciplinary	2283	Active	Passed	62	77	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2278	Active	Passed	64	89	18	63
12/28/2017	Molecular Engineering Building	140-B	Interdisciplinary	2294	Active	Passed	60	68	18	87
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2297	Active	Passed	63	86	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2298	Active	Passed	62	73	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2296	Active	Passed	62	68	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2299	Active	Passed	63	74	18	63
12/28/2017	Molecular Engineering Building	140	Interdisciplinary	2306	Active	Passed	63	89	18	63
1/9/2018	Molecular Engineering Building	340	Interdisciplinary	2263	Active	Passed	60	82	18	63
9/27/2017	MORE HALL	319A	Civil Engineering	1547	Active	Passed	68	114	24	84
9/27/2017	MORE HALL	319	Civil Engineering	1234	Active	Passed	65	118	24	60
9/27/2017	MORE HALL	324	Civil Engineering	1562	Active	Passed	65	128	24	88
9/27/2017	MORE HALL	034F	Civil Engineering	915	Active	Failed	68	161	18	52
9/27/2017	MORE HALL	324	Civil Engineering	1561	Active	Passed	69	115	24	52
9/27/2017	MORE HALL	324	Civil Engineering	1560	Active	Passed	67	114	22	64
9/27/2017	MORE HALL	324	Civil Engineering	1559	Active	Passed	68	134	24	64
9/27/2017	MORE HALL	320	Civil Engineering	1744	Active	Passed	70	107	18	88
9/27/2017	MORE HALL	319	Civil Engineering	1233	Active	Passed	64	105	24	60
12/27/2017	MORE HALL	314	Civil Engineering	1854	Active	Passed	60	90	28	38
11/16/2017	MUELLER HALL	183	Materials Science and Engineering	844	Active	Failed	67	160	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
11/16/2017	MUELLER HALL	165	Materials Science and Engineering	853	Active	Passed	60	86	18	50
11/16/2017	MUELLER HALL	189	Materials Science and Engineering	856	Active	Failed	65	155	24	50
11/16/2017	MUELLER HALL	187	Materials Science and Engineering	849	Active	Passed	64	119	24	50
11/16/2017	MUELLER HALL	185	Materials Science and Engineering	857	Active	Passed	63	85	18	50
11/16/2017	MUELLER HALL	183	Materials Science and Engineering	916	Active	Passed	65	93	24	50
11/16/2017	MUELLER HALL	167	Materials Science and Engineering	848	Active	Passed	62	99	24	50
11/16/2017	MUELLER HALL	166	Materials Science and Engineering	855	Active	Passed	60	90	24	62
8/2/2017	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2568	Active	Passed	65	74	18	63
8/22/2017	Nanoengineering & Science Building	G-61	Nano Engineering & Sciences	2556	Active	Passed	65	69	18	63
8/22/2017	Nanoengineering & Science Building	G-61	Nano Engineering & Sciences	2555	Active	Passed	62	65	18	63
8/22/2017	Nanoengineering & Science Building	G-66	Nano Engineering & Sciences	2554	Active	Passed	65	77	18	63
8/22/2017	Nanoengineering & Science Building	G-66	Nano Engineering & Sciences	2553	Active	Passed	62	74	18	63
8/22/2017	Nanoengineering & Science Building	G-67	Nano Engineering & Sciences	2552	Active	Passed	63	65	18	63
8/22/2017	Nanoengineering & Science Building	G-91B	Nano Engineering & Sciences	2551	Active	Passed	61	69	18	63
8/22/2017	Nanoengineering & Science Building	180	Nano Engineering & Sciences	2560	Active	Passed	60	74	18	63
8/22/2017	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2567	Active	Passed	65	71	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2570	Active	Passed	64	74	18	63
8/22/2017	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2566	Active	Passed	63	76	18	63
8/22/2017	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2565	Active	Passed	64	76	18	63
8/22/2017	Nanoengineering & Science Building	G-62C	Nano Engineering & Sciences	2557	Active	Passed	63	73	18	63
8/22/2017	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2564	Active	Passed	65	73	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
8/22/2017	Nanoengineering & Science Building	280	Nano Engineering & Sciences	2563	Active	Passed	65	69	18	63
8/22/2017	Nanoengineering & Science Building	180	Nano Engineering & Sciences	2561	Active	Passed	58	76	18	63
8/22/2017	Nanoengineering & Science Building	180	Nano Engineering & Sciences	2562	Active	Passed	59	74	18	63
8/22/2017	Nanoengineering & Science Building	G-91B	Nano Engineering & Sciences	2550	Active	Passed	64	78	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2575	Active	Passed	63	76	18	63
8/22/2017	Nanoengineering & Science Building	G-64	Nano Engineering & Sciences	2558	Active	Passed	63	72	18	63
8/22/2017	Nanoengineering & Science Building	480A	Nano Engineering & Sciences	2579	Active	Passed	63	76	18	63
8/22/2017	Nanoengineering & Science Building	480A	Nano Engineering & Sciences	2577	Active	Passed	63	65	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2576	Active	Passed	64	75	18	63
8/22/2017	Nanoengineering & Science Building	480A	Nano Engineering & Sciences	2578	Active	Passed	63	73	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2574	Active	Passed	65	74	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2573	Active	Passed	64	70	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2572	Active	Passed	65	77	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2571	Active	Passed	63	74	18	63
8/22/2017	Nanoengineering & Science Building	380	Nano Engineering & Sciences	2569	Active	Passed	64	70	18	63
8/22/2017	Nanoengineering & Science Building	G-64	Nano Engineering & Sciences	2559	Active	Passed	64	73	18	63
12/18/2017	OCEAN SCIENCES	437	School of Oceanography	1707	Active	Failed	66	176	18	50
12/18/2017	OCEAN SCIENCES	540	School of Oceanography	1711	Active	Passed	64	95	18	62
12/18/2017	OCEAN SCIENCES	444B	School of Oceanography	1704	Active	Passed	61	86	18	62
12/18/2017	OCEAN SCIENCES	437	School of Oceanography	1706	Active	Passed	66	139	18	50
12/18/2017	OCEAN SCIENCES	531	School of Oceanography	1718	Active	Passed	65	97	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/18/2017	OCEAN SCIENCES	532	School of Oceanography	1710	Active	Failed	61	100	18	88
12/18/2017	OCEAN SCIENCES	444	School of Oceanography	1703	Active	Passed	65	120	18	62
12/18/2017	OCEAN SCIENCES	527	School of Oceanography	1717	Active	Passed	65	97	18	62
12/18/2017	OCEAN SCIENCES	432	School of Oceanography	1699	Active	Passed	65	106	18	62
12/18/2017	OCEAN SCIENCES	537	School of Oceanography	1721	Active	Failed	50	0	18	50
12/18/2017	OCEAN SCIENCES	531	School of Oceanography	1719	Active	Passed	64	106	18	62
12/18/2017	OCEAN SCIENCES	440	School of Oceanography	1700	Active	Failed	63	107	18	62
12/18/2017	OCEAN SCIENCES	440	School of Oceanography	1701	Active	Failed	64	120	18	62
12/18/2017	OCEAN SCIENCES	446	School of Oceanography	2580	Active	Passed	62	121	18	25
12/19/2017	OCEAN SCIENCES	346	School of Oceanography	1698	Active	Passed	62	103	18	62
12/19/2017	OCEAN SCIENCES	344	School of Oceanography	1697	Active	Passed	63	100	18	62
12/19/2017	OCEAN SCIENCES	340	School of Oceanography	1696	Active	Passed	62	106	18	62
12/19/2017	OCEAN SCIENCES	336	School of Oceanography	1695	Active	Passed	63	118	18	62
12/19/2017	OCEAN SCIENCES	332	School of Oceanography	1694	Active	Passed	63	102	18	62
12/19/2017	OCEAN SCIENCES	447	School of Oceanography	1709	Active	Passed	64	108	18	62
12/19/2017	OCEAN SCIENCES	544	School of Oceanography	1714	Active	Passed	63	108	18	62
12/19/2017	OCEAN SCIENCES	435	School of Oceanography	1705	Active	Passed	63	103	18	62
12/19/2017	OCEAN SCIENCES	543	School of Oceanography	1724	Active	Passed	64	101	18	88
12/19/2017	OCEAN SCIENCES	539	School of Oceanography	1722	Active	Passed	63	100	18	62
12/19/2017	OCEAN SCIENCES	544	School of Oceanography	1713	Active	Passed	62	87	18	88
12/19/2017	OCEAN SCIENCES	543	School of Oceanography	1725	Active	Passed	63	98	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/19/2017	OCEAN SCIENCES	547	School of Oceanography	1726	Active	Passed	63	110	18	62
12/19/2017	OCEAN SCIENCES	547	School of Oceanography	1727	Active	Passed	62	101	18	88
12/19/2017	OCEAN SCIENCES	546	School of Oceanography	1716	Active	Passed	63	100	18	62
12/19/2017	OCEAN SCIENCES	546	School of Oceanography	1715	Active	Passed	63	103	18	62
12/19/2017	OCEAN SCIENCES	544	School of Oceanography	1712	Active	Passed	62	100	8	88
12/19/2017	OCEAN SCIENCES	535	School of Oceanography	1720	Active	Passed	63	110	18	62
10/30/2017	OCEAN TEACHING BUILDING	202	School of Oceanography	1119	Active	Passed	71	91	22	36
10/30/2017	OCEAN TEACHING BUILDING	206	School of Oceanography	707	Active	Passed	69	102	18	36
10/30/2017	OCEAN TEACHING BUILDING	309	School of Oceanography	743	Active	Passed	71	120	18	36
10/30/2017	OCEAN TEACHING BUILDING	309	School of Oceanography	744	Active	Passed	80	109	24	36
10/30/2017	OCEAN TEACHING BUILDING	306	School of Oceanography	1601	Active	Passed	72	114	24	38
10/30/2017	OCEAN TEACHING BUILDING	302	School of Oceanography	708	Active	Passed	73	109	29	36
10/30/2017	OCEAN TEACHING BUILDING	304	School of Oceanography	1126	Active	Passed	70	124	24	36
10/30/2017	OCEAN TEACHING BUILDING	305	School of Oceanography	1043	Active	Passed	71	106	21	48
10/30/2017	OCEAN TEACHING BUILDING	302	School of Oceanography	709	Active	Passed	73	110	29	36
3/28/2017	OCEANOGRAPHY BUILDING	216B	School of Oceanography	736	Active	Passed	70	130	27	60
3/31/2017	OCEANOGRAPHY BUILDING	118	School of Oceanography	559	Inactive	Passed	0	0	18	34
3/31/2017	OCEANOGRAPHY BUILDING	315	School of Oceanography	745	Active	Passed	68	146	27	60
3/31/2017	OCEANOGRAPHY BUILDING	306	Quaternary Research Center	1769	Inactive	Passed	0	0	10	62
1/9/2018	OCEANOGRAPHY BUILDING	316	School of Oceanography	739	Active	Passed	66	102	28	40
2/20/2018	ONR CONF CENTER	CHEM LAB	Forest Management and Engineering Division	1622	Inactive	Passed	0	0	0	36

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
12/20/2017	PHYSICS/ASTRON BAR	B021	Physics	1240	Active	Passed	59	109	18	63
12/20/2017	PHYSICS/ASTRON BAR	A079	Biology Program	1259	Active	Passed	64	121	18	63
12/20/2017	PHYSICS/ASTRON BAR	A079	Biology Program	1258	Active	Passed	63	108	18	63
12/20/2017	PHYSICS/ASTRON BAR	B009	Physics	1236	Active	Passed	55	105	18	38
12/20/2017	PHYSICS/ASTRON BAR	B328B	Astronomy	1251	Active	Passed	61	95	30	38
12/20/2017	PHYSICS/ASTRON BAR	B034C	Physics	1585	Active	Passed	58	93	0	38
12/20/2017	PHYSICS/ASTRON BAR	A051	Biology Program	1257	Active	Passed	62	107	18	63
12/20/2017	PHYSICS/ASTRON BAR	B027	Physics	1237	Active	Passed	54	107	18	63
12/20/2017	PHYSICS/ASTRON BAR	B049	Physics	1246	Active	Passed	60	117	18	63
12/20/2017	PHYSICS/ASTRON BAR	B308	Physics	1248	Active	Passed	61	99	30	62
12/20/2017	PHYSICS/ASTRON BAR	B055A	Physics	1241	Active	Passed	57	102	18	62
12/20/2017	PHYSICS/ASTRON BAR	B059A	Physics	1244	Inactive	Passed	0	0	0	50
12/20/2017	PHYSICS/ASTRON BAR	B069	Physics	1242	Active	Passed	59	96	18	38
12/20/2017	PHYSICS/ASTRON BAR	B092	Physics	1243	Active	Passed	60	109	18	63
12/20/2017	PHYSICS/ASTRON BAR	B090	Physics	1245	Active	Passed	50	112	18	86
12/20/2017	PHYSICS/ASTRON BAR	B208B	Physics	1250	Active	Passed	58	99	18	38
12/20/2017	PHYSICS/ASTRON BAR	B228	Physics	1249	Active	Passed	58	113	18	62
12/20/2017	PHYSICS/ASTRON BAR	B051	Physics	1238	Active	Passed	56	103	18	38
12/20/2017	PHYSICS/ASTRON BAR	B050B	Physics	1247	Active	Passed	55	118	18	62
1/9/2018	PORTAGE BAY BLDG	112	Applied Physics Laboratory	901	Active	Passed	63	112	28	52
1/9/2018	PORTAGE BAY BLDG	129	School of Fisheries	918	Active	Passed	63	130	18	52

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
1/9/2018	PORTAGE BAY BLDG	118A	School of Fisheries	900	Active	Passed	66	114	29	52
1/9/2018	PORTAGE BAY BLDG	M-12	School of Fisheries	677	Inactive	Passed	0	0	0	34
1/9/2018	PORTAGE BAY BLDG	114	Applied Physics Laboratory	734	Active	Passed	66	122	24	52
1/9/2018	PORTAGE BAY BLDG	102K	Applied Physics Laboratory	729	Active	Passed	61	92	22	64
1/9/2018	PORTAGE BAY BLDG	102N	Applied Physics Laboratory	730	Active	Passed	63	98	18	63
1/12/2018	PORTAGE BAY BLDG	166	School of Fisheries	930	Inactive	Passed	0	0	0	36
3/29/2017	RAITT HALL	125	Materials Science and Engineering	612	Active	Passed	68	94	24	84
3/29/2017	RAITT HALL	128A	Nutritional Sciences	613	Inactive	Passed	64	121	18	32
5/8/2017	RAITT HALL	235	Epidemiology	615	Active	Passed	54	111	18	32
1/12/2018	ROBERTS HALL	221	Materials Science and Engineering	995	Active	Passed	61	96	28	38
1/12/2018	ROBERTS HALL	216	Materials Science and Engineering	994	Active	Passed	63	109	28	50
1/12/2018	ROBERTS HALL	214	Materials Science and Engineering	993	Active	Passed	62	118	20	50
1/12/2018	ROBERTS HALL	204	Materials Science and Engineering	992	Active	Passed	63	109	28	38
1/12/2018	ROBERTS HALL	202	Materials Science and Engineering	991	Active	Passed	59	84	18	62
1/12/2018	ROBERTS HALL	129	Materials Science and Engineering	986	Active	Passed	63	130	28	38
1/12/2018	ROBERTS HALL	138	Materials Science and Engineering	990	Active	Passed	64	142	26	38
1/12/2018	ROBERTS HALL	138	Materials Science and Engineering	989	Active	Passed	64	139	26	38
1/12/2018	ROBERTS HALL	134	Materials Science and Engineering	987	Active	Passed	65	101	28	38
1/12/2018	ROBERTS HALL	134	Materials Science and Engineering	988	Active	Passed	65	119	28	38
9/13/2017	ROOSEVELT I	2299	Environmental Health	1852	Active	Passed	61	84	18	32
9/13/2017	ROOSEVELT I	2310	Environmental Health	1903	Active	Passed	59	70	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
9/13/2017	ROOSEVELT I	2295	Environmental Health	1829	Active	Passed	65	109	19	48
9/13/2017	ROOSEVELT I	2295	Environmental Health	1850	Active	Passed	67	95	18	32
9/13/2017	ROOSEVELT I	2297	Environmental Health	1828	Active	Passed	67	112	18	60
9/13/2017	ROOSEVELT I	284	Environmental Health	1537	Active	Passed	65	102	18	60
9/13/2017	ROOSEVELT I	2299	Environmental Health	1853	Active	Passed	58	64	18	32
9/13/2017	ROOSEVELT I	276	Environmental Health	1540	Active	Passed	66	96	18	60
9/13/2017	ROOSEVELT I	281	Environmental Health	1539	Active	Passed	66	94	18	60
9/13/2017	ROOSEVELT I	281	Environmental Health	1538	Active	Passed	65	91	18	60
9/13/2017	ROOSEVELT I	280	Environmental Health	1541	Active	Passed	72	116	18	60
9/13/2017	ROOSEVELT I	284	Environmental Health	1536	Active	Passed	66	119	18	60
9/13/2017	ROOSEVELT I	2310	Environmental Health	1902	Active	Passed	58	81	18	50
9/13/2017	ROOSEVELT I	260B	Environmental Health	1545	Active	Passed	68	113	24	60
9/13/2017	ROOSEVELT I	2312	Environmental Health	1904	Active	Passed	57	75	18	50
9/13/2017	ROOSEVELT I	1110	Environmental Health	2022	Active	Passed	60	72	18	36
9/13/2017	ROOSEVELT I	1109	Environmental Health	2023	Active	Passed	65	78	18	32
9/13/2017	ROOSEVELT I	260	Environmental Health	1542	Active	Passed	69	105	24	48
9/13/2017	ROOSEVELT I	260	Environmental Health	1543	Active	Passed	67	113	28	60
9/13/2017	ROOSEVELT I	260	Environmental Health	1544	Active	Passed	66	117	22	60
9/13/2017	ROOSEVELT I	2295	Environmental Health	1851	Active	Passed	64	72	18	32
9/13/2017	ROOSEVELT I	268	Environmental Health	1535	Active	Passed	68	115	18	60
2/16/2018	ROOSEVELT II	E184	Unknown	2545	Active	Passed	67	81	18	50

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
2/16/2018	ROOSEVELT II	169	Metabolism, Endocrinology, and Nutrition, Medicine	1565	Active	Passed	61	140	18	38
6/26/2017	SLU 1 BROTMAN	336	Medicine	1870	Active	Passed	63	116	18	62
6/26/2017	SLU 1 BROTMAN	317	Medicine	1874	Active	Passed	62	129	18	62
6/26/2017	SLU 1 BROTMAN	417	Medicine	1879	Active	Passed	60	98	18	62
6/26/2017	SLU 1 BROTMAN	355	Medicine	1873	Active	Passed	63	120	18	62
6/26/2017	SLU 1 BROTMAN	357	Medicine	1875	Active	Passed	61	119	18	62
6/26/2017	SLU 1 BROTMAN	341	Medicine	1872	Active	Passed	62	103	18	62
6/26/2017	SLU 1 BROTMAN	331	Medicine	1869	Active	Passed	60	102	18	62
6/26/2017	SLU 1 BROTMAN	424	Medicine	1878	Active	Passed	60	101	18	62
6/26/2017	SLU 1 BROTMAN	441	Medicine	1880	Active	Passed	62	121	18	62
6/26/2017	SLU 1 BROTMAN	348	Medicine	1876	Active	Passed	61	105	18	62
6/26/2017	SLU 1 BROTMAN	455	Medicine	1881	Active	Passed	61	130	18	62
6/26/2017	SLU 1 BROTMAN	431	Medicine	1877	Active	Passed	60	112	18	62
6/26/2017	SLU 1 BROTMAN	436	Medicine	1883	Active	Passed	60	101	18	62
6/26/2017	SLU 1 BROTMAN	449	Medicine	1882	Active	Passed	62	126	18	62
7/10/2017	SLU 1 BROTMAN	217	Medicine	1868	Active	Passed	62	111	18	62
7/10/2017	SLU 1 BROTMAN	155	Medicine	1860	Active	Passed	62	109	18	62
7/10/2017	SLU 1 BROTMAN	151	Medicine	1862	Active	Passed	60	106	18	62
7/10/2017	SLU 1 BROTMAN	141	Medicine	1861	Active	Passed	62	115	18	62
7/10/2017	SLU 1 BROTMAN	241	Medicine	1866	Active	Passed	62	99	18	62
7/10/2017	SLU 1 BROTMAN	248	Medicine	1865	Active	Passed	61	97	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/10/2017	SLU 1 BROTMAN	255	Medicine	1864	Active	Passed	64	107	18	62
7/10/2017	SLU 1 BROTMAN	236	Medicine	1867	Active	Passed	60	111	18	62
7/19/2017	SLU 1 BROTMAN	325	Medicine	1871	Active	Passed	60	99	18	62
7/19/2017	SLU 1 BROTMAN	118	Medicine	1863	Active	Passed	63	110	18	62
7/11/2017	SLU 2 Lab North	512	Stem Cell Research	2109	Active	Passed	65	103	18	62
7/11/2017	SLU 2 Lab North	528	Stem Cell Research	2108	Active	Passed	65	122	18	62
7/12/2017	SLU 2 Lab North	117	Department of Medicine	2137	Active	Passed	63	95	18	62
7/12/2017	SLU 2 Lab North	217	Department of Medicine	2127	Active	Passed	58	104	18	62
7/12/2017	SLU 2 Lab North	227	Pharmacology	2126	Active	Passed	50	103	18	62
7/12/2017	SLU 2 Lab North	318	Department of Medicine	2124	Active	Passed	59	112	18	62
7/12/2017	SLU 2 Lab North	235	Department of Medicine	2125	Active	Passed	67	130	18	62
7/12/2017	SLU 2 Lab North	428	Stem Cell Research	2118	Active	Passed	59	100	18	62
7/12/2017	SLU 2 Lab North	418	Stem Cell Research	2117	Active	Passed	67	103	18	62
7/12/2017	SLU 2 Lab North	328	Department of Medicine	2123	Active	Passed	63	94	18	62
7/12/2017	SLU 2 Lab North	125	Nuclear Medicine	2136	Active	Passed	58	100	18	62
7/19/2017	SLU 2 Lab North	112	Department of Medicine	2139	Active	Passed	63	107	18	38
7/11/2017	SLU 2 Lab South	586	Biochemistry	2142	Active	Passed	64	112	18	48
7/11/2017	SLU 2 Lab South	509	Pharmacology	2140	Active	Passed	64	99	18	38
7/11/2017	SLU 2 Lab South	544	Biological Structure	2110	Active	Passed	65	97	18	62
7/11/2017	SLU 2 Lab South	522	Pharmacology	2141	Active	Passed	61	101	18	48
7/11/2017	SLU 2 Lab South	586	Biochemistry	2112	Active	Passed	64	135	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/11/2017	SLU 2 Lab South	522	Pharmacology	2111	Active	Passed	61	101	18	62
7/12/2017	SLU 2 Lab South	144	Diabetesand Obesity Center for Excellence	2132	Active	Passed	53	97	18	62
7/12/2017	SLU 2 Lab South	244	Diabetes and Obesity Center for Excellence	2128	Active	Passed	58	98	18	62
7/12/2017	SLU 2 Lab South	185	Diabetes and Obesity Center for Excellence	2134	Active	Passed	52	107	18	62
7/12/2017	SLU 2 Lab South	422	Biochemistry	2143	Active	Passed	61	98	18	48
7/12/2017	SLU 2 Lab South	422	Stem Cell Research	2115	Active	Passed	63	106	18	62
7/12/2017	SLU 2 Lab South	163	Diabetes and Obesity Center for Excellence	2135	Active	Passed	58	112	18	62
7/12/2017	SLU 2 Lab South	386	Lung Biology	2121	Active	Passed	55	102	18	62
7/12/2017	SLU 2 Lab South	185	Bioengineering	2184	Active	Passed	58	105	18	48
7/12/2017	SLU 2 Lab South	344	Lung Biology	2119	Active	Passed	51	108	18	62
7/12/2017	SLU 2 Lab South	222	Diabetes and Obesity Center for Excellence	2129	Active	Passed	52	97	18	62
7/12/2017	SLU 2 Lab South	263	Diabetes and Obesity Center for Excellence	2131	Active	Passed	52	91	18	62
7/12/2017	SLU 2 Lab South	322	Lung Biology	2120	Active	Passed	55	108	18	62
7/12/2017	SLU 2 Lab South	122	Diabetesand Obesity Center for Excellence	2133	Active	Passed	50	95	18	62
7/12/2017	SLU 2 Lab South	463	Lung Biology	2113	Active	Passed	60	100	18	62
7/12/2017	SLU 2 Lab South	P125A	Medicine	2452	Active	Passed	48	71	18	51
7/12/2017	SLU 2 Lab South	486	Metabolism, Endocrinology, and Nutrition, Medicine	2144	Active	Passed	55	102	18	48
7/12/2017	SLU 2 Lab South	486	Metabolism, Endocrinology, and Nutrition, Medicine	2114	Active	Passed	52	99	18	62

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/12/2017	SLU 2 Lab South	286	Diabetes and Obesity Center for Excellence	2130	Active	Passed	63	94	18	62
7/12/2017	SLU 2 Lab South	444	Stem Cell Research	2116	Active	Passed	54	104	18	62
7/12/2017	SLU 2 Lab South	363	Lung Biology	2122	Active	Passed	61	94	18	62
7/18/2017	SLU3 PHASE 3.1	324	School of Medicine	2438	Active	Passed	62	105	18	72
7/18/2017	SLU3 PHASE 3.1	128	School of Medicine	2450	Active	Passed	59	79	18	48
7/18/2017	SLU3 PHASE 3.1	272	School of Medicine	2446	Active	Passed	62	96	18	72
7/18/2017	SLU3 PHASE 3.1	254	School of Medicine	2444	Active	Passed	60	102	18	72
7/18/2017	SLU3 PHASE 3.1	272	School of Medicine	2445	Active	Passed	61	86	18	72
7/18/2017	SLU3 PHASE 3.1	E772	Immunology	2453	Active	Passed	61	116	18	63
7/18/2017	SLU3 PHASE 3.1	146	School of Medicine	2451	Active	Passed	60	83	18	48
7/18/2017	SLU3 PHASE 3.1	154A	School of Medicine	2448	Active	Passed	59	84	18	72
7/18/2017	SLU3 PHASE 3.1	224	School of Medicine	2439	Active	Passed	60	95	18	72
7/18/2017	SLU3 PHASE 3.1	E224	Ophthalmology	2440	Active	Passed	62	85	18	63
7/18/2017	SLU3 PHASE 3.1	242	School of Medicine	2441	Active	Passed	61	96	18	72
7/18/2017	SLU3 PHASE 3.1	242	School of Medicine	2442	Active	Passed	62	102	18	72
7/18/2017	SLU3 PHASE 3.1	E372	Immunology	2434	Active	Passed	62	104	18	63
7/18/2017	SLU3 PHASE 3.1	E254	Ophthalmology	2443	Active	Passed	60	84	18	63
7/18/2017	SLU3 PHASE 3.1	128	School of Medicine	2449	Active	Passed	58	89	18	63
7/18/2017	SLU3 PHASE 3.1	624	School of Medicine	2417	Active	Passed	61	89	15	72
7/18/2017	SLU3 PHASE 3.1	E554	Immunology	2421	Active	Passed	60	99	18	63
7/18/2017	SLU3 PHASE 3.1	E554	Immunology	2422	Active	Passed	61	100	18	63

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/18/2017	SLU3 PHASE 3.1	E542	Medicine	2424	Active	Passed	62	94	18	63
7/18/2017	SLU3 PHASE 3.1	E542	Medicine	2423	Active	Passed	61	94	18	63
7/18/2017	SLU3 PHASE 3.1	E524	Department of Medicine	2425	Active	Passed	63	81	18	63
7/18/2017	SLU3 PHASE 3.1	524	School of Medicine	2426	Active	Passed	62	89	18	72
7/18/2017	SLU3 PHASE 3.1	E472	Immunology	2428	Active	Passed	60	100	18	63
7/18/2017	SLU3 PHASE 3.1	E472	Immunology	2427	Active	Passed	60	107	18	63
7/18/2017	SLU3 PHASE 3.1	654	School of Medicine	2418	Active	Passed	62	96	18	72
7/18/2017	SLU3 PHASE 3.1	E342	Immunology	2436	Active	Passed	59	90	18	63
7/18/2017	SLU3 PHASE 3.1	642	School of Medicine	2416	Active	Passed	60	85	18	72
7/18/2017	SLU3 PHASE 3.1	E324	Immunology	2437	Active	Passed	62	102	18	63
7/18/2017	SLU3 PHASE 3.1	E572	Immunology	2419	Active	Passed	61	92	18	63
7/18/2017	SLU3 PHASE 3.1	E572	Immunology	2420	Active	Passed	60	81	18	63
7/18/2017	SLU3 PHASE 3.1	E454	Immunology	2430	Active	Passed	60	99	18	63
7/18/2017	SLU3 PHASE 3.1	454	School of Medicine	2429	Active	Passed	63	106	18	72
7/18/2017	SLU3 PHASE 3.1	E442	Immunology	2432	Active	Passed	61	112	18	63
7/18/2017	SLU3 PHASE 3.1	E442	Immunology	2431	Active	Passed	63	95	18	63
7/18/2017	SLU3 PHASE 3.1	E422	Immunology	2433	Active	Passed	62	97	18	63
7/18/2017	SLU3 PHASE 3.1	E352	Immunology	2435	Active	Passed	60	101	18	63
7/18/2017	SLU3 PHASE 3.1	654	School of Medicine	2415	Active	Passed	61	83	18	72
7/19/2017	SLU3 PHASE 3.1	282	School of Medicine	2447	Active	Passed	62	112	18	48
8/29/2017	SUZZALLO LIBRARY	560C	Unknown	2543	Active	Passed	70	136	18	68

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
5/31/2017	U W MED CTR/NW	220	Laboratory Medicine	2542	Active	Passed	57	83	18	63
5/31/2017	U W MED CTR/NW	NW 053	Radiology	1016	Active	Passed	59	109	28	38
5/31/2017	U W MED CTR/NW	NW 145	Laboratory Medicine	275	Active	Passed	64	99	18	64
5/31/2017	U W MED CTR/NW	NW 053	Radiology	1014	Active	Passed	58	104	28	38
5/31/2017	U W MED CTR/NW	NW 047	Radiology	1010	Active	Passed	63	145	20	50
5/31/2017	U W MED CTR/NW	NW 053	Radiology	1017	Inactive	Passed	0	0	18	58
5/31/2017	U W MED CTR/NW	NW 290A	Radiology	1162	Active	Passed	61	126	20	38
5/31/2017	U W MED CTR/NW	NW 225	Laboratory Medicine	286	Active	Passed	56	119	18	64
5/31/2017	U W MED CTR/NW	NW 225	Laboratory Medicine	287	Active	Passed	57	110	18	60
5/31/2017	U W MED CTR/NW	NW 177	Laboratory Medicine	1736	Active	Passed	58	99	18	50
5/31/2017	U W MED CTR/NW	NW 147B	Laboratory Medicine	276	Active	Passed	63	103	18	50
5/31/2017	U W MED CTR/NW	NW 142D		274	Active	Passed	61	124	28	40
5/31/2017	U W MED CTR/NW	NW 125F	Pathology	273	Active	Passed	62	104	27	64
5/31/2017	U W MED CTR/NW	NW 050	Radiology	1728	Active	Passed	56	107	20	38
5/31/2017	U W MED CTR/NW	NW 049	Radiology	1012	Active	Passed	59	102	27	50
5/31/2017	U W MED CTR/NW	NW 053	Radiology	1013	Active	Passed	63	125	24	38
5/31/2017	U W MED CTR/NW	NW 049	Radiology	1011	Active	Passed	60	109	27	86
3/21/2018	U W MED CTR/NW	NW 176	Laboratory Medicine	277	Active	Passed	63	100	22	88
5/19/2017	UW-SODO Tracer Lab		Radiology	2533	Active	Passed	68	121	18	52
5/19/2017	UW-SODO Tracer Lab		Radiology	2534	Active	Passed	68	94	18	63
10/2/2017	Vandergraaff Accelerator	165	Physics	1084	Active	Passed	72	104	79	222

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
10/2/2017	Vandergraaff Accelerator	166	Physics	817	Active	Passed	63	98	18	60
10/2/2017	Vandergraaff Accelerator	162	Physics	816	Active	Passed	64	106	22	60
10/2/2017	Vandergraaff Accelerator	162	Physics	815	Active	Passed	66	104	24	60
11/28/2017	WILCOX HALL	249	Bioengineering	1324	Active	Passed	63	86	18	60
11/28/2017	WILCOX HALL	039	Materials Science and Engineering	1591	Active	Passed	65	104	28	64
11/28/2017	WILCOX HALL	169	Civil Engineering	117	Active	Passed	62	105	18	48
11/28/2017	WILCOX HALL	130	Materials Science and Engineering	1260	Active	Passed	63	121	18	60
11/28/2017	WILCOX HALL	131	Materials Science and Engineering	1261	Active	Passed	65	144	18	60
11/28/2017	WILCOX HALL	136	Materials Science and Engineering	114	Active	Passed	63	89	29	32
11/28/2017	WILCOX HALL	136	Materials Science and Engineering	113	Active	Passed	62	107	29	32
11/28/2017	WILCOX HALL	139	Materials Science and Engineering	1735	Active	Passed	63	106	18	62
11/28/2017	WILCOX HALL	141	Materials Science and Engineering	1262	Active	Passed	65	135	22	60
11/28/2017	WILCOX HALL	230A	Bioengineering	1264	Active	Passed	65	120	25	36
11/28/2017	WILCOX HALL	271	Civil Engineering	128	Active	Passed	61	98	27	38
11/28/2017	WILCOX HALL	247	Bioengineering	1263	Active	Passed	59	95	18	60
11/28/2017	WILCOX HALL	239	Bioengineering	1265	Active	Passed	63	85	18	48
7/24/2017	WINKENWERDER HALL	217	Forest Management and Engineering Division	66	Inactive	Failed	58	0	30	44
7/24/2017	WINKENWERDER HALL	106	Forest Management and Engineering Division	57	Active	Passed	62	105	23	44
7/24/2017	WINKENWERDER HALL	110	Forest Management and Engineering Division	59	Active	Passed	65	102	30	44
7/24/2017	WINKENWERDER HALL	112	Forest Management and Engineering Division	58	Inactive	Failed	70	156	24	44

Survey Date	Building Name	Room	Department Name	HOOD ID	Hood Status	Hood Function	DBA	Vel Ave	Sash Height	Sash Width
7/24/2017	WINKENWERDER HALL	212	Forest Management and Engineering Division	63	Active	Passed	63	91	18	44
7/24/2017	WINKENWERDER HALL	213	Forest Management and Engineering Division	62	Active	Passed	72	106	29	44
7/24/2017	WINKENWERDER HALL	214	Forest Management and Engineering Division	65	Active	Passed	64	121	22	44
7/24/2017	WINKENWERDER HALL	215	Forest Management and Engineering Division	64	Active	Passed	69	112	26	44
7/24/2017	WINKENWERDER HALL	216	Forest Management and Engineering Division	67	Inactive	Failed	56	75	17	44
7/24/2017	WINKENWERDER HALL	209	Forest Management and Engineering Division	60	Inactive	Failed	52	30	30	44
7/24/2017	WINKENWERDER HALL	208	Forest Management and Engineering Division	61	Inactive	Passed	0	0	18	44
10/11/2017	WINKENWERDER HALL	114	Forest Management and Engineering Division	56	Active	Passed	78	139	24	44